



procedures and without devices to block geomagnetically induced currents (GIC) from collapsing the grid.<sup>2</sup>

Twenty-five years have now passed since the March 1989 Hydro Quebec blackout conclusively proved that solar storms can collapse electric grids. Yet NERC and the electric utility industry failed to act on their own initiative to protect the grid and the American public, forcing FERC to issue its first *sua sponte* order in the history of the NERC regulatory regime. Now comes NERC with a proposed reliability standard that would sidestep FERC Order 779 and instead grant protection to electric utilities but not to the public. Every year of delay and legal maneuvering is another year of playing Russian Roulette with the sun:

---

<sup>2</sup> The coronal mass ejection (CME) events of July 23-24, 2012 are now recognized to have involved two overlapping or “cannibalizing” CMEs. Among the rapidly expanding scientific literature assessing these space weather events and implications for protection of electric grids are the following articles, incorporated in these Comments by reference: C. T. Russell, et al., “The Very Unusual Interplanetary Coronal Mass Ejection of 2012 July 23: A Blast Wave Mediated by Solar Energetic Particles,” *Astrophysical J.* 770: 38 (5 pp.), June 10, 2013; Daniel N. Baker, “The Major Solar Eruptive Event in July 2012: Defining Extreme Space Weather Scenarios,” Am. Geophysical Union, San Francisco, Dec. 9, 2013, with same title, forthcoming, Space Weather Workshop, Boulder, CO., April 2014; C. M. Ngwira, et al., “Simulation of the 23 July 2012 extreme space weather event: What if this extremely rare CME was Earth directed?” *Space Weather*, 11: 671-679 (Dec. 2013); Y. D. Liu, et al., “Observations of an extreme storm in interplanetary space caused by successive coronal mass ejections,” *Nature Communications*, 5: article no. 3481, 18 March 2014.

Depending upon the energetic forces of a CME event, predictive models of the coupling of CMEs with geomagnetic fields may enable estimates of grid impacts as far as one hour in advance. However, the more energetic CMEs tend to travel at speeds in excess of 3,000 km per second, and provide far shorter and less reliable warning times. See the forthcoming presentation at the Space Weather Workshop, Boulder, CO. in April 2014: Daniel Weimer, “Rapid, low-cost prediction of geomagnetic perturbations from real-time solar wind measurements.”



**July 23, 2012 Coronal Mass Ejection as Observed from Stereo Satellite**

## **Background**

On November 13, 2013, NERC petitioned the Commission to approve proposed Reliability Standard EOP-010-1. NERC states that the proposed Reliability Standard is just, reasonable, not unduly discriminatory or preferential, and in the public interest. Further, NERC maintains that the proposed Reliability Standard satisfies the Commission's directive in Order No. 779 corresponding to the development and submission of the First Stage GMD Reliability

Standards.<sup>3</sup> Consistent with the NERC petition, FERC proposes to approve Reliability Standard EOP-010-1 as just, reasonable, not unduly discriminatory or preferential, and in the public interest.

## **Summary of Reasons for Remand**

Reliability Standard EOP-010-1 is a perfunctory standard that will require no mandatory protection from solar storms and associated geomagnetic disturbance (GMD) to the bulk electric system. The “Measures and Requirements” of Standard EOP-010-1 are merely an empty framework lacking specific mitigative actions and lacking specific responsibilities of owner and operator entities. Under the proposed standard, Reliability Coordinators and Transmission Operators need do little more than monitor space weather, have a paper GMD Operating Plan on file, and document self-determined actions during solar storms—actions which may or may not be prudent or quantifiably effective. In return for these pro forma tasks, which will neither increase grid reliability nor protect against grid collapse during a severe solar storm, all NERC Functional Entities would receive liability protection for following a federally-approved reliability standard.

The Foundation for Resilient Societies was a ballot participant in the NERC standard-setting process, submitting comprehensive and well-reasoned comments.<sup>4</sup> As a result, we got a first-person perspective into the sausage grinder of NERC standard-setting.

Previous NERC standards for cyber protection and vegetation management had required lengthy redrafts and ballots over several years, but the tight schedule of FERC Order 779 deprived NERC of the luxury of delay. The first ballot on Standard EOP-010-1 failed, a common occurrence in the NERC process. As an apparent means to expedite Standard EOP-010-1 and assure passage, the Standard Drafting Team quickly redrafted the standard to eliminate mandatory participation by Balancing Authorities, despite their vital importance in dispatching Generator Operators during emergency operations.

---

<sup>3</sup> FERC Order No. 779, 78 FR 30747 (May 23, 2013), 143 FERC ¶ 61,147, reh’g denied, 144 FERC ¶ 61,113 (2013).

<sup>4</sup> See our comments in standard-setting for proposed Standard EOP-010-1 in Appendix 1 of this Comment.

The Foundation for Resilient Societies diligently objected to the original draft and also to the October 2013 gutting of the proposed standard by the Standards Drafting Team. The Foundation cited research on showing GMD impacts on critical equipment providing reactive power support in transmission networks with high-end voltage between 100 kV and 200 kV. Nonetheless, our objections were ignored by a Standards Drafting Team mostly composed of representatives from utilities particularly vulnerable to GMD. Despite key harms to the proposed Standard EOP-010-1—including loss of mandatory participation by Balancing Authorities and Generator Operators—inflicted, and with compliance to the tight schedule imposed in FERC Order 779 within reach, the further degraded “reliability standard” passed easily on the second ballot with 91.95% voting in favor.

The electric utility industry clearly recognized in this instance how to design a so-called “reliability standard” that, though foreseeably ineffective in a severe solar storm, would avert financial liability to the electric utility industry even while civil society and its courts might collapse from long-term outages. In this instance and others, a key feature of the NERC standard-setting process was to progressively water down requirements until the proposed standard obviously benefited the ballot participants and therefore could pass. In the process, any remaining public benefit was diluted beyond perceptibility, except perhaps to those well-steeped in NERC standard-setting.

Next step in the NERC standard-setting process was consideration by the purportedly independent NERC Board of Trustees, in a nominally public proceeding as required by NERC By-Laws and Section 215 of the Federal Power Act. A week before the scheduled board meeting, the Foundation for Resilient Societies appealed its concerns on Standard EOP-010-1 directly to the Trustees; see our November 7, 2013 letter to the NERC Board of Trustees found at Appendix 2 to these Comments. The NERC board declined even to discuss Standard EOP-010-1 in public session and instead voted unanimously to approve it as drafted.

The draft of Standard EOP-010-1 now submitted to FERC for final approval excludes Generator Operators, ironically the entities best situated to use GIC monitors, operating procedures, and

hardware protective equipment to prevent geomagnetically induced currents from impacting the bulk transmission system and also Balancing Authorities, the entities most closely directing Generator Operators. Additional defects in the standard are legion and should be readily apparent to any reasonable person taking time to examine the factual record. But in terms of legal authority, the final check and balance on NERC standard-setting process lies solely with the five FERC Commissioners.

As the facts we present below will show, proposed Reliability Standard EOP-010-1 is not just, not technically reasonable, unfairly discriminates among Functional Entities, and provides regulatory and competitive preferences for certain Generator Operators. Without remand by the FERC Commissioners and subsequent modification at NERC, the proposed standard is not in the public interest.

Per FERC's own guidance in FERC Order No. 672,<sup>5</sup> "a proposed Reliability Standard should be designed to apply throughout the interconnected North American Bulk-Power System, to the maximum extent that is achievable with a single Reliability Standard."

Remand to NERC of proposed Standard EOP-010-1 should be ordered with a 60-day or 90-day deadline to resubmit a standard with mandatory participation by Generator Operators and Balancing Authorities, and with inclusion of all reactive power support equipment and bulk power transmission networks operating between 100 kV and 200 kV at the high voltage end.

## **Specific Defects in Proposed Standard EOP-010-1**

### **Trivial Requirements and Measures**

The sum and total of "Requirements and Measures" in Standard EOP-010-1 are:

#### **B. Requirements and Measures**

**R1.** Each Reliability Coordinator shall develop, maintain, and implement a GMD Operating Plan that coordinates GMD Operating Procedures or Operating Processes within its Reliability Coordinator Area. At a minimum, the GMD Operating Plan shall

---

<sup>5</sup> See Order No. 672, Docket RM05-30-000, 18 C.F.R. Part 39, 71 FR 8662 (2006) at para. 331.¶30,157.

include: [Violation Risk Factor: Medium] [Time Horizon: Long-term Planning, Operations Planning, Same-day Operations, Real-time Operations]

1.1 A description of activities designed to mitigate the effects of GMD events on the reliable operation of the interconnected transmission system within the Reliability Coordinator Area.

1.2 A process for the Reliability Coordinator to review the GMD Operating Procedures or Operating Processes of Transmission Operators within its Reliability Coordinator Area.

**M1.** Each Reliability Coordinator shall have a current GMD Operating Plan meeting all the provisions of Requirement R1; evidence such as a review or revision history to indicate that the GMD Operating Plan has been maintained; and evidence to show that the plan was implemented as called for in its GMD Operating Plan, such as dated operator logs, voice recordings, or voice transcripts.

**R2.** Each Reliability Coordinator shall disseminate forecasted and current space weather information to functional entities identified as recipients in the Reliability Coordinator's GMD Operating Plan. [Violation Risk Factor: Medium] [Time Horizon: Same-day Operations, Real-time Operations]

**M2.** Each Reliability Coordinator shall have evidence such as dated operator logs, voice recordings, transcripts, or electronic communications to indicate that forecasted and current space weather information was disseminated as stated in its GMD Operating Plan.

**R3.** Each Transmission Operator shall develop, maintain, and implement a GMD Operating Procedure or Operating Process to mitigate the effects of GMD events on the reliable operation of its respective system. At a minimum, the Operating Procedure or Operating Process shall include: [Violation Risk Factor: Medium] [Time Horizon: Long-term Planning, Operations Planning, Same-day Operations, Real-Time Operations]

3.1. Steps or tasks to receive space weather information.

3.2. System Operator actions to be initiated based on predetermined conditions.

3.3. The conditions for terminating the Operating Procedure or Operating Process.

**M3.** Each Transmission Operator shall have a GMD Operating Procedure or Operating Process meeting all the provisions of Requirement R3; evidence such as a review or revision history to indicate that the GMD Operating Procedure or Operating Process has been maintained; and evidence to show that the Operating Procedure or Operating Process was implemented as called for in its GMD Operating Procedure or Operating Process, such as dated operator logs, voice recordings, or voice transcripts.

In essence, Standard EOP-010-1 proposes a balkanized self-regulatory scheme, where Reliability Coordinators and Transmission Operators would devise their own plans and procedures within

timeframe buckets (“Long-term Planning, Operations Planning, Same-day Operations, Real-Time Operations”) but there would be no mandatory mitigative actions within the timeframes. GMD Operating Procedures of Transmission Operators would be subject to review by Reliability Coordinators. There would be no mandatory external review of GMD Operating Plans of Reliability Coordinators.

Several decades of experience and technical research on the impact of GMD on electric grids—including GMD operating procedure templates developed by NERC’s own GMD Task Force—indicate mitigative actions that electric utilities could take during solar storms. For example, actions in the NERC template for GMD Operating Procedures for Transmission Operators include:

### **Actions Available to the Operator**

The following are possible actions for Transmission Operators based on available lead-time:

#### **Long lead-time (1-3 days in advance, storm possible)**

1. Increase situational awareness
  - a. Assess readiness of black start generators and cranking paths
  - b. Notify field personnel as necessary of the potential need to report to individual substations for on-site monitoring (if not available via SCADA/EMS)
2. Safe system posturing (only if supported by study; allows equipment such as transformers and SVCs to tolerate increase reactive/harmonic loading; reduces transformer operating temperature, allowing additional temperature rise from core saturation; prepares for contingency of possible loss of transmission capacity)
  - a. Return outaged equipment to service (especially series capacitors where installed)
  - b. Delay planned outages
  - c. Remove shunt reactors
  - d. Modify protective relay settings based on predetermined harmonic data corresponding to different levels of GIC (provided by transformer manufacturer).

#### **Day-of-event (hours in advance, storm imminent):**

1. Increase situational awareness
  - a. Monitor reactive reserve
  - b. Monitor for unusual voltage, MVAR swings, and/or current harmonics
  - c. Monitor for abnormal temperature rise/noise/dissolved gas in transformers
  - d. Monitor geomagnetically induced current (GIC) on banks so-equipped

- e. Monitor MVAR loss of all EHV transformers as possible
  - f. Prepare for unplanned capacitor bank/SVC/HVDC tripping
  - g. Prepare for possible false SCADA/EMS indications if telecommunications systems are disrupted (e.g., over microwave paths)
2. Safe system posturing (only if supported by study)
    - a. Start off-line generation, synchronous condensers
    - b. Enter conservative operations with possible reduced transfer limits
    - c. Ensure series capacitors are in-service (where installed)

**Real-time actions (based on results of day-of-event monitoring):**

1. Safe system posturing (only if supported by study)
  - a. Selective load shedding
  - b. Manually start fans/pumps on selected transformers to increase thermal margin (check that oil temperature is above 50° C as forced oil flow at lower temperatures may cause static electrification)
2. System reconfiguration (only if supported by study)
  - a. Remove transformer(s) from service if imminent damage due to overheating (possibly automatic by relaying)
  - b. Remove transmission line(s) from service (especially lines most influenced by GMD)

Despite the fact that the mitigative actions in the GMD Operating Procedure Template for Transmission Operators were approved by the NERC Planning Committee, the Standards Drafting Team saw fit to include none of these mitigative actions in Standard EOP-010-1.

The omission of any specific mitigative actions in Standard EOP-010-1 is technically unreasonable, contrary to the public interest, and should be remanded by the Commissioners for prompt remediation.

**Willful Blindness to Real-Time Impacts of Geomagnetic Disturbance**

Geomagnetically-Induced Current (GIC) monitors are commercially available and can be purchased for as little as \$10,000 to \$15,000 each.<sup>6</sup> Nonetheless, Standard EOP-010-1 has no requirement for GIC monitoring or mandatory sharing of GIC data with Reliability Coordinators, Balancing Authorities, and/or Transmission Operators. Without real-time GIC data, Reliability Coordinators would force “blind” operating procedures upon Functional Entities. Moreover,

---

<sup>6</sup> See Resilient Societies Findings and Recommendations to the Maine Public Utilities Commission in Maine PUC Docket 2013-00415, October 15, 2013 and December 18, 2013. Costs of commercially available GIC monitoring and automated remote readout have declined from \$200,000 per unit to \$10,000 to \$15,000 per monitoring unit over the past two years. See <http://resilientsocieties.org/docketfilings.html>, last accessed March 23, 2014..

because of the arbitrary exclusion of Generator Operators from mandatory participation in planning of GMD operating procedures, in event of a severe GMD it is doubtful that Generator Operators could reliably and promptly execute “Reliability Directives” or “Operating Instructions during an Emergency.” Further, without Standard EOP-010-1 jurisdiction over Generator Operators, these operators are less likely to install GIC monitors and to develop reliable procedures for real-time reporting of GIC data and transformer condition to Reliability Coordinators, Balancing Authorities, and Transmission Operators. These obvious deficiencies could impose tremendous economic losses upon the public in event of blackout—losses that might be prevented by modest expenditures in GIC monitors by Transmission Operators and Generator Operators. Notably, lack of collected and reported GIC data will impede post-GMD event forensic analysis and impede assignment of liability to electric utilities. Willful operational blindness to the real-time impact of GMD on the Bulk Electric System is economically unjustifiable, technically unreasonable, contrary to the public interest, and should be remanded by the Commissioners for corrective alterations to Standard EOP-010-1.

### **Exemption of the Significant Parts of the Bulk Electric System**

While the FERC-approved Bulk Electric System definition includes transmission at voltages at 100kV and above, and while multiple GMD impacts on Static VAR Compensators and other equipment operating between 100kV and 200kV were reported by electric utilities during the March 1989 solar storm, Standard EOP-010-1 would exempt Transmission Operators with equipment operating between 100 kV and 200 kV. Many Transmission Operators operate Static Var Compensators, capacitors, and other equipment between 100 kV and 200 kV, equipment designed to provide reactive power and to stabilize transmission networks during GMD. See reference to specific equipment voltages in our balloting comment to NERC, found in Appendix 1, referring to Static VAR Compensators and other equipment operating between 100 kV and 200 kV commonly installed in the past two decades. Below is a listing of March 13, 1989 storm impacts on critical equipment operating at less than 200 kV, as disclosed by a FERC-sponsored study:

## March 13, 1989 Geomagnetic Disturbance

### Chronology of Reported North American Power Grid Events

Adapted from Pages A2-2 to A2-8 of "Geomagnetic Storms and Their Impacts on the U.S. Power Grid"  
Oak Ridge National Laboratory, January 2010

Event No.	Date	Time (EST)		Area or System	Event	Base kV	Comments
		From	To				
29	3/13/1989	245		Minn. Power	Capacitor	115	Lost capacitor bank at Nashwauk. Neut overcurrent relay
44	3/13/1989	608		Cent. Hud.	Capacitor	69	Pulvers Corners capacitor trip
47	3/13/1989	615		APS	Capacitor	138	7 Capacitors tripped
54	3/13/1989	618		Va. Pwr.	Capacitor	115	Virginia Beach
57	3/13/1989	619		Cent. Hud.	Capacitor	115	Hurley Ave. capacitor trip
94	3/13/1989	1645	2000	WPL	Voltage	138	Various voltage problems. Regulators hunting
100	3/13/1989	1655		Atl. Elec.	Voltage	69	
108	3/13/1989	1658		BPA	Capacitor	115	Tripped by neutral time ground at 4 substations
175	3/13/1989	2017		NEPOOL	Capacitor	115	Orrington capacitors (1, 2, &3) opened and would not close
183	3/13/1989	2020	2030	Atl. Elec.	Voltage	138	
192	3/13/1989	2032		PJM		69	Nazareth Capacitors tripped

These real-world and non-trivial GMD impacts during a moderate storm with geoelectric fields of only 2 volts/kilometer invalidate NERC Standard Drafting Team's summary determination, which claims: "The effect of GIC in networks less than 200 kV has negligible impact on the reliability of the interconnected transmission system."

We researched reactive power support equipment installed in the United States and found three sources: lists of reference accounts published by ABB and Siemens and individual company disclosures. Notably, there was a high degree of overlap between the three sources. It appears ABB produces the vast majority of SVC/STATCOM for the United States. Based on the ABB sample, we estimate that about 25% of SVC/STATCOM units within the bulk electric system of the United States operate between 100 kV and 200 kV. Reactive power is in particularly short supply during GMD events because transformers in half-cycle saturation consume reactive power. Unexpected tripping of reactive power resources can cause both system separation and

cascading system collapse. In fact, the proximate cause of the March 1989 Hydro Quebec blackout, occurring in only 93 seconds, was loss of seven SVC's, all tripping within a 59 second interval.<sup>7</sup>

Below is an example list of reactive power resources within the United States operating between 100 kV and 200 kV, the vast majority installed since 1989:

<b>Examples of Reactive Power Resources 100-200 kV within United States</b>						
<b>Equipment</b>	<b>Utility</b>	<b>Location</b>	<b>Voltage (kV)</b>	<b>First Year of Service</b>	<b>Inductive Rating (MW)</b>	<b>Capacitive Rating (MW)</b>
SVC	AEP	Beaver Creek	138	1978	0	0
SVC	Kansas Gas & Electric	Murray Gill, KS	138	1985	25	200
SVC	Kansas Gas & Electric	Gordon Evans, KS	138	1985	0	300
SVC	Alaska Energy Authority	Soldatna, AK	115	1991	40	70
SVC	Alaska Energy Authority	Daves Creek, AK	115	1991	10	25
SVC	Virginia Power	Colington, VA	115	1996	30	167
STATCOM	COM Central and South West Corp	Eagle Pass HVDC	138	1999	72	72
SVC	Connectiv	Nelson	138	1999	100	150
SVC	ISO Ispat	Ispat	138	1999	0	200
STATCOM	Austin Energy	Holly, USA	138	2003	80	110
SVC	Pacific Gas & Electric	Potero, CA	115	2003	100	240
SVC	Golden Valley Electric Association	Jarvis Creek	138	2004	8	45
SVC	Georgia Power Co	Noth Dublin, GA	115	2005	unknown	unknown
SVC	Duke Power	Beckerdite	100	2006	100	300
SVC	Tucson Electric Power	Tucson, AZ	138	2006	75	200
SVC	Dominion Power	Colington, VA	115	2007	0	0
SVC	Nstar	Barnstable, MA	115	2008	113	225
SVC	Oncor	Renner 1	138	2008	265	300
SVC	Oncor	Parkdale 1	138	2008	265	300
SVC	Oncor	Parkdale 2	138	2008	265	300
SVC	Oncor	Renner 2	138	2009	265	300
SVC	AEP	Hamilton 1	138	2011	25	100
SVC	AEP	Hamilton 2	138	2011	25	100
SVC	Pepco (PHI)	Nelson	135	2011	0	0
SVC	Rochester Gas & Electric	Station 124, NY	115	2011	100	200
SVC	Pepco (PHI)	Ocean City, MD	138	2012	75	75
SVC	Entergy	Porter, TX	138	unknown	unknown	unknown
STATCOM	San Diego G&E	Talega, CA	138	unknown	unknown	unknown
STATCOM	Vermont Electric	Burlington, VT	115	unknown	unknown	unknown
Source: ABB, Siemens, Company Disclosures						

<sup>7</sup> See S. Renaud and S. Guillon, "Hydro-Québec and GIC: Power Network Studies and Simulation Developments," Presentation of HQ to the JRC Workshop, Ispra, Italy, Oct. 29, 2013, at VG 6, 16, 18 and 24 of 56. See [http://ipsc.jrc.ec.europa.eu/fileadmin/repository/sta/SpaceWeatherWorkshop/Session-3\\_Guillon.pdf](http://ipsc.jrc.ec.europa.eu/fileadmin/repository/sta/SpaceWeatherWorkshop/Session-3_Guillon.pdf).

Reactive power support equipment and real-time equipment monitoring of that equipment should be a mandatory element in GMD Operating Procedures because unexpected tripping can cause voltage instability, system separation, and cascading failure that impairs the reliability of the bulk electric system contrary to the mandates of Section 215 of the Federal Power Act. Therefore, we ask the FERC Commissioners to remand to include owners and operators of all stabilizing and reactive power equipment operating between 100 kV and 200 kV within the mandates of the standard.

The pseudo-scientific study of the NERC Standard Drafting Team, “Network Applicability, Project 2013-03, EOP-010-1, Summary Determination” is an example of a report that is consistent with apparently predetermined policy goals of NERC’s membership—to reduce the scope of mandatory participation in GMD mitigation and to reduce potential financial liabilities—while ignoring available evidence that equipment operating between 100 kV and 200 kV is vulnerable to GMD and that significant and grid-essential reactive power capacity operates between 100 kV and 200 kV.

The arbitrary exemption of networks operating between 100 kV and 200 kV, without any specific study by owners and operators, is technically unreasonable, discriminatory, preferential, and inconsistent with real-world scientific evidence. The Commissioners should remand to eliminate this exemption.

### **Exemption of Balancing Authorities and Operationally Infeasible Communication**

Balancing Authorities have specific real-time responsibilities in the NERC Functional Model<sup>8</sup>, including:

- “Directs resources (Generator Operators and Load-Serving Entities) to take action to ensure balance in real time.”

---

<sup>8</sup>“Reliability Functional Model Technical Document Version 5,” Functional Model Working Group, North American Electric Reliability Corporation (May 2010), available at [http://www.nerc.com/pa/Stand/Functional%20Model%20Archive%201/FM\\_Technical\\_Document\\_V5\\_2009Dec1.pdf](http://www.nerc.com/pa/Stand/Functional%20Model%20Archive%201/FM_Technical_Document_V5_2009Dec1.pdf), last accessed March 22, 2014.

- “Directs Transmission Operator (or Distribution Provider) to reduce voltage or shed load if needed to ensure balance within its Balancing Authority Area.”
- “Directs Generator Operators to implement redispatch for congestion management as directed by the Reliability Coordinator.”
- “Implements corrective actions and emergency procedures as directed by the Reliability Coordinator.”

While Balancing Authorities have real-time responsibilities that would be essential during GMD events, Balancing Authorities are arbitrarily exempted from specific responsibility in Standard EOP-010-1. Standard EOP-010-1 assumes that the real-time responsibilities of Balancing Authorities under fast-moving GMD conditions could be assumed by Reliability Coordinators, per the NERC Functional Model normally applicable to non-GMD conditions. In fact, deficiencies in the NERC Functional Model during fast-moving GMD conditions are why a mandatory standard for GMD operating procedures should be required.

The NOAA Space Weather Prediction Center would give only a 15-60 minute warning of a severe solar storm.<sup>9</sup> NERC standards for communication during an emergency require two-way person-to-person communication, including a requirement for three-part communication where information is verbally stated by a party initiating a communication, the information is repeated back correctly to the party that initiated the communication by the second party that received the communication, and the same information is verbally confirmed to be correct by the party who initiated the communication.<sup>10</sup> In the United States, there are 16 Reliability

---

<sup>9</sup> This 15-60 minute severe solar storm warning time is taken from NERC’s own template for operating procedures “Geomagnetic Disturbance Operating Procedure Template, Transmission Operator,” North American Electric Reliability Corporation, available at [http://www.nerc.com/docs/pc/gmdtf/Template\\_TOP.pdf](http://www.nerc.com/docs/pc/gmdtf/Template_TOP.pdf), last accessed March 22, 2014..

<sup>10</sup> This explanation of “three-part” communication is taken from “NERC Standard COM-003-1—Operating Personnel Communications Protocols Standard, Standard Development Roadmap, Draft 1,” November 18, 2009. The NERC requirements and terminology for communication are evolving through a series of standards. Nonetheless, the essential requirement for two-way, three-part, person-to-person communication has persisted through all versions of the communications standards.

Coordinators, 103 Balancing Authorities, 186 Transmission Operators, and 1,324 Generator Operators with GSU high-side voltage of 200 kV or greater.<sup>11</sup>

With hundreds of potentially affected Generator Operators and Transmission Operators during a GMD event, and as little as 15 minutes warning, there would be little opportunity for two-way, “three part,” person-to-person communication directly from Reliability Coordinators. Moreover, sequential communication from Reliability Coordinator to Balancing Authority, and then from Balancing Authority to Generator Operator—as a potential work-around—would double time required for communication.

The presumption that sixteen Reliability Coordinators could directly communicate with up to 1,500 Transmission and Generator Operators during severe GMD events with a warning time of as little as 15 minutes defies commonsense, as does sequential indirect communication through Balancing Authorities. The NERC proposal to exempt Balancing Authorities from GMD operating procedures is technically flawed, operationally unworkable on its face, and should be remanded by the Commissioners.

### **Exemption of Generator Operators**

Generator Step Up (GSU) transformers are a major GMD vulnerability according to FERC’s own study by the Oak Ridge National Laboratory, “Geomagnetic Storms and Their Impacts on the U.S. Power Grid.”<sup>12</sup> The Oak Ridge report also recognized that nuclear plants may be particularly vulnerable during solar storms:

Because the U.S. transformer population as a whole is very large and non-homogeneous, it is difficult to fully recognize trends, though studies have confirmed compelling associations between transformer failures over a 25-year period and geomagnetic storm activity (Reference 2-7). Rather, a rash of failures in the small and more homogeneous population of nuclear plant GSU transformers (~100 units) in the U.S. suggested a compelling linkage to the March ’89 storm and GIC exposure. Within 2 years after the

---

<sup>11</sup> Entity counts from databases of the U.S. Energy Information Administration, March 2014 and *Reliability Standard for Geomagnetic Disturbance Operations*, Notice of Proposed Rulemaking, 146 FERC ¶ 61,015 (Jan. 16, 2014) (“GMD NOPR”), 79 FR 3547 (Jan. 22, 2014).

<sup>12</sup> “Geomagnetic Storms and Their Impacts on the U.S. Power Grid,” Oak Ridge Laboratory, (Jan. 2010), available at: [www.ornl.gov/sci/ees/etsd/pes/pubs/ferc\\_Meta-R-319.pdf](http://www.ornl.gov/sci/ees/etsd/pes/pubs/ferc_Meta-R-319.pdf), last accessed March 22, 2014.

March '89 exposure, 11 nuclear plants noted failures of the large GSU transformers, in addition to the Salem failure (Reference 2-7).

On April 3, 1994 a moderate intensity storm occurred. During this storm a GSU transformer at Zion Nuclear plant (on the outskirts of Chicago) failed catastrophically. The failure was so severe that the transformer tank, containing thousands of gallons of oil, ruptured and started a major fire in the yard at the plant, which eventually involved control circuits and other sensitive systems. The fire also spread into the generator hydrogen cooled isobus inside the plant. In many postmortem analyses of transformer failures, it is very difficult to assess the failure cause, given unknowns about the unique design variations and unique operational exposure of each transformer. In particular, static electrification was a failure mode of transformers of this vintage, and would be unrelated to GIC exposure. Considering the unknowns and multiple plausible failure causes, very few definitive failure diagnoses can be expected. The operator of the plant facility has resisted the association of this failure with the geomagnetic storm event, however they had not been undertaking any effort to monitor for GIC in the transformer or at any other locations in their regional transmission network. Observations of GIC were made at utilities elsewhere north, south, east and west relative to their location. The space weather conditions that spawned the April 3, 1994 storm were associated with long-duration and recurrent solar activity sources. Therefore, storm conditions occurred from early April to mid-April. Over that same period of time, the local utility also experienced major GSU transformer failures at the Braidwood nuclear plant (April 5, 1994) and at the Powerton coal plant (April 15, 1994). Again, the operator has resisted the association of these failures with GIC, even though the timing of these events would appear to be extraordinarily coincidental.

The Oak Ridge report recognized the vulnerability of generating equipment in addition to GSU transformers:

Generators are another important apparatus that is potentially at-risk for permanent and debilitating damage due to unusually large GIC exposures. Prior investigative analysis has determined that there are two important aspects of vulnerability for generators that could lead to permanent damage (Reference 2-8). The high levels of harmonic currents flowing in the generator transformer due to half-cycle saturation are the immediate cause of both exposure concerns. The first concern is one of generator rotor electrical heating due to the coupling of various harmonic currents that act as negative sequence flows in the electrical windings of generators. There is considerable concern that standard relays designed to protect for rotor heating would not act properly in sensing this added current flow. The second and potentially more important concern arises from the interaction of the harmonic currents and the natural resonant frequencies of turbines on large MVA high-pressure turbine generators. Events that excite vibrations in the turbines at their

natural frequencies can readily lead to mechanical damage to these high-speed, high pressure blades. Permanent and widespread damage to large MVA generators in the U.S. would likely cause especially long-term debilitating damage to the power grid.

Permanent damage is not the only potential effect on generators; harmonics and off-sequence current caused by GIC could trigger protective devices, reducing generation during GMD events and causing unexpected contingencies.

Despite a documented record of significant vulnerability to GMD, Generator Operators are exempted from specific responsibility in Standard EOP-010-1. Standard EOP-010-1 exempts Generator Operators purportedly because Generator Operators have no requirement for GIC monitoring devices and absent GIC data, “the GOP would not have the technical basis for taking steps on its own and would instead take steps based on the RC or TOP’s Operating Plans, Processes, or Procedures.” This convenient rationale is proposed in the NERC document “Functional Entity Applicability, Project 2013-03, EOP-010-1, Summary Determination” and ignores that the lack of required GIC monitoring on equipment is completely the result of a defectively drafted standard and associated cancellation of a standards project for equipment monitoring. Between the date of FERCs issuance of Order No. 779 (May 16, 2013), when a mandatory equipment monitoring standard was under development, and the October 2013 redraft of Standard EOP-010-1 to exclude Generator Operators from participation, the NERC RISC Committee (on May 5, 2013), then the NERC Standards Committee (on June 5, 2013) eliminated the proposed equipment monitoring standard (Standards Project 2012-01, “Equipment Monitoring and Diagnostic Devices”), citing the Operating Committee’s interest in further “research” that was never specified nor implemented. The trashing of this sister standard then became one of the rationales for eliminating Generator Operators from participation in Standard EOP-010-1.

In its whitepaper, “Functional Entity Applicability, Project 2013-03, EOP-010-1, Summary Determination,” NERC proposes that Generator Operators pay up to \$250,000 for a technical study to see if their equipment might be vulnerable to GIC rather than install a GIC monitor for

\$10,000 to \$15,000 and find out for sure.<sup>13</sup> And even after a finding of vulnerability for the Generator Operator, the Standard EOP-010-1 would not directly apply to the operator.

For roughly the same cost as a paper study, a Generator Operator could install a neutral ground blocking system that includes GIC monitoring equipment. This would both protect the critical GSU transformer at a generating facility, and concurrently preclude the entry of geomagnetically induced currents (GICs) into the Bulk Electric System, thereby reducing risks to other bulk electric system-connected equipment that may be vulnerable to damage.

Why might Generator Operators prefer paper studies to hardware protection? To avert liability due to incomplete or poorly designed hardware protection, or from gross negligence by generator operators, and to reduce competition from other Generator Operators who might be tempted to provide more reliable and available electric service.

FERC's Commissioners should not be a willful party to a scheme to create barriers to competition. FERC-approved reliability standards should encourage the reach for greater grid reliability by regional Generator Operators and Transmission Operators who seek to keep GIC out of their interconnected systems, in contrast to other Generator Operators and Transmission Operators who may prefer mere liability shielding and who are apparently indifferent to cost-effective opportunities to block harmful GIC from the bulk electric system.

Per para. 354 of FERC Order No. 672 (2006), the Commission should "not eliminate the ability of the market to respond to reliability needs with market-oriented solutions."<sup>14</sup> If all Generator Operators are exempted from adopting low-cost GIC equipment monitors, and exempted from mandatory participation in GMD operating procedures, how realistic is it for those Generator Operators and associated Transmission Operators who would seek to compete at higher levels of reliability to do so, and to obtain tariff approvable cost recoveries via FERC?

---

<sup>13</sup> For example, Bonneville Power Administration paid \$253,000 for modeling of GIC in their network. See "FY2013 Technology Innovation Portfolio," Bonneville Power Administration, available at <http://www.bpa.gov/Doing%20Business/TechnologyInnovation/Documents/2013/201303-FY2013-Portfolio-TI-External.pdf>, last accessed March 22, 2014.

<sup>14</sup> FERC Order No. 672 (2006) ¶ 30,161.

Proposed Standard EOP-010-1 will discourage understanding as to which transmission lines and transformers are introducing more or less GIC and harmonics into a regional grid and a regional economy, despite FERC Order No. 672's para. 355, wherein "the planning and operation of the bulk electric system shall recognize that reliability is an essential requirement of a robust economy"; and that "reliability standards shall not give any market participant an unfair competitive advantage."<sup>15</sup>

The non-participation of Generator Operators in Standard EOP-010-1 is inconsistent with the real world practices of Generator Operators during solar storms. Increasingly, Generator Operators have been installing GIC monitors for their GSU transformers. Generator Operators have also downrated their GSU transformers during solar storms. For example, below is a table of actions that nuclear plant operators have taken during solar storms, summarized from Power Reactor Status Reports submitted to the Nuclear Regulatory Commission:

<b>Reduced Power at Generator Operators Due to Geomagnetic Disturbances</b>					
<u>Date of Report</u>	<u>MinDate</u>	<u>MaxDate</u>	<u>Unit Name</u>	<u>Power</u>	<u>Comment</u>
7/16/2000	7/6/2000	7/26/2000	SALEM 1	80%	REDUCED POWER DUE TO GRID DISTURBANCE CAUSED BY SOLAR MAGNETIC DISTURBANCE
3/31/2001	3/21/2001	4/10/2001	HOPE CREEK	65%	REDUCED POWER DUE TO SOLAR MAGNETIC DISTURBANCE'S
4/1/2001	3/22/2001	4/11/2001	HOPE CREEK	65%	HOLDING POWER DUE TO SOLAR MAGNETIC DISTURBANCE'S
4/12/2001	4/2/2001	4/22/2001	HOPE CREEK	80%	REDUCED POWER DUE TO SOLAR MAGNETIC DISTURBANCE
4/18/2001	4/8/2001	4/28/2001	HOPE CREEK	80%	REDUCED POWER DUE TO SOLAR MAGNETIC DISTURBANCES ON "C" MAIN POWER TRANSFORMER
10/2/2001	9/22/2001	10/12/2001	HOPE CREEK	80%	REDUCED POWER DUE TO SOLAR MAGNETIC DISTURBANCES AFFECTING THE MAIN TRANSFORMER
11/6/2001	10/27/2001	11/16/2001	SALEM 1	75%	HOLDING POWER AT THIS LEVEL DUE TO SOLAR MAGNETIC DISTURBANCES
11/24/2001	11/14/2001	12/4/2001	HOPE CREEK	78%	SOLAR MAGNETIC DISTURBANCE
10/29/2003	10/19/2003	11/8/2003	HOPE CREEK	80%	REDUCED POWER DUE TO SOLAR MAGNETIC DISTURBANCES
11/8/2004	10/29/2004	11/18/2004	SALEM 1	77%	REDUCED POWER DUE TO SOLAR MAGNETIC DISTURBANCE
Source: NRC Power Reactor Status Reports					

The real time actions of Generator Operators during solar storms are a result of specific knowledge that these operators have of their own equipment vulnerability. Some Generator Operators seek to reduce entry of GIC into their regional transmission networks, perhaps to increase on-cost sales and capacity utilization factors. Yet, with the proposed Standard EOP-

<sup>15</sup> Ibid. (2006), para. 355.

010-1 and its barriers to competition for greater reliability, Generator Operators still have no requirement for GMD Operating Procedures. Instead, Standard EOP-010-1 presumes that Reliability Coordinators, twice removed from Generator Operators, will be responsible for the individual situations of these operators during fast moving solar storms.

We urge the Commission to reject barriers to competition by both Generator Operators and interconnected Transmission Operators. Resilient Societies endorses reliability standards that *encourage* higher reliability as a positive factor in market competition. Resilient Societies concurs in one of CenterPoint Energy's comments on criteria for reliability standard-setting preceding issuance of FERC Order No. 672:

[I]t is appropriate and in the public interest for Reliability Standards to affect competition in certain instances ... it is reasonable and in the public interest, and consistent with the intent of EAct, to establish Reliability Standards that afford an advantage to competitors that enhance the reliability of the grid over competitors that do not.<sup>16</sup>

NERC's own GMD Task Force developed an Operating Procedure Template for Generators Operators that was approved by the Planning Committee.<sup>17</sup> Below are the specific mitigative actions in this template:

#### **Actions Available to the Operator**

The following are possible actions for Generator Operators based on available lead-time:

#### **Day-of-event (hours in advance, storm imminent):**

1. Increase situational awareness
  - a. Monitor for unusual voltage, MVAR swings, and/or current harmonics
  - b. Monitor for Abnormal temperature rise/noise/dissolved gas in transformers
  - c. Monitor geomagnetically induced current (GIC2) on banks so-equipped
  - d. Monitor MVAR loss of all EHV GSU transformers as possible
2. Safe system posturing (only if supported by study)
  - a. Redispatch generation (possible implement autorunback if available)

---

<sup>16</sup> FERC Order No. 672 (2006), para. 374, ¶ 31,204.

<sup>17</sup> "Geomagnetic Disturbance Operating Procedure Template, Generator Operator," North American Electric Reliability Corporation, available at [http://www.nerc.com/docs/pc/gmdtf/Template\\_GOP.pdf](http://www.nerc.com/docs/pc/gmdtf/Template_GOP.pdf), last accessed March 22, 2014.

**Real-time actions for moderate solar storms (based on results of day-of-event monitoring):**

1. Safe system posturing
    - a. Manually start fans/pumps on selected transformers to increase thermal margin (check that oil temperature is above 50° C as forced oil flow at lower temperatures may cause static electrification)
  1. Unloading reactive load of on-line generation (provides operating margin in case of loss of system reactive capability from SVC/shunt capacitors which may trip due to harmonics)
  2. System reconfiguration (only if supported by study)
- Remove transformer(s) from service if imminent damage due to overheating (possibly automatic by relaying)

In summary, despite documented vulnerability and existence of NERC-developed mitigative actions, Standard EOP-010-1 exempts Generator Operators from any mandatory requirements and thereby also effectively exempts these operators from legal liability due to inaction during solar storms. As a result, the standard is preferential to Generator Operators and degrades competition for reliability and availability of electric service. Moreover, the exemption of Generator Operators is technically unreasonable and operationally unworkable. Accordingly, the exemption of Generator Operators should be remanded by the Commissioners for prompt elimination.

**Lack of Requirement for Quantified Contingency Planning**

The fundamental basis for GMD operating procedures is to increase spinning reserves, other operating reserves, and reactive power resources while derating vulnerable transmission and generation facilities. Spinning reserves, reactive power, generation, and transmission are all quantifiable, allowing for contingency planning in advance of a GMD event. As has been experienced in prior storms such as the March 1989 storm, a large number of correlated failures can all occur nearly simultaneously, requiring better and more comprehensive operational posturing than normally allowed via 10 minute or 25 minute reserve periods. Nonetheless, Standard EOP-010-1 contains no requirement for quantified contingency planning specific to fast-moving GMD conditions.

Past experience has shown that Reliability Coordinators cannot be relied upon to devise technically sound and quantifiably effective operating procedures as part of a self-regulation scheme. For example, ISO New England, located in a region susceptible to GMD, has planned

operating reserves lower than the sum of contingencies already experienced during moderate solar storms.

Within ISO New England, the Chester Static Var Compensator (SVC), the Phase II HVDC tie, and the Seabrook nuclear power plant have all been impacted by past solar storms.

The Chester SVC supports 700 MW of imported power from Kenswick, New Brunswick to Orrington, Maine and another 2,000 MW of imported power on the Phase II HVDC tie. An unexpected tripping of the Chester Substation Static Var Compensator (SVC), providing reactive power support for 2,700 MW of transmission, occurred during a moderate solar storm on March 24, 1991.

The Phase II HVDC tie consists of two poles rated at approximately 2,000 MW together. Loading of the Phase II ties on many days is close to capacity. It is fortunate that a cascading blackout did not occur when both poles of the Phase II HVDC tie tripped out on October 28, 1991 during a moderate solar storm.

The Seabrook nuclear power plant is rated at 1,247 MW capacity. An unexpected outage of the Seabrook nuclear power plant occurred on November 10, 1998 when a transformer failed after the November 8-9 solar storm. Power for Seabrook was reduced to 30% of capacity on October 29, 2003 during a moderate solar storm, according to the NRC Power Reactor Status Report. Power for Seabrook was reduced to 68% of capacity on July 16, 2012 during a minor solar storm, according to the NRC Power Reactor Status Report.

As has been experienced in prior solar geomagnetic storms, such as the March 1989 storm, a large number of correlated failures can all occur nearly simultaneously, requiring better and more comprehensive operational posturing, real time monitoring and reporting of GIC and equipment condition, and mandatory participation of both Balancing Authorities and Generator Operators.

According to the ISO-New England planning document "[ISO-NE 2014 Operable Capacity Analysis](#)," the Operating Reserve Requirement, on a planning basis, is 2,375MW. The Operating

Reserve consists of Ten Minute Spinning Reserve, Ten Minute Non-Spinning Reserve, and Thirty Minute Operating Reserve. Under some circumstances, final warning of a GMD event would be as little as 15 minutes, precluding use of Thirty Minute Operating Reserve. The planned 2,375 MW Operating Reserve compares to a total of 3,947 MW of ISO-New England resources demonstrably at risk during solar storms.<sup>18</sup>

Increasingly, High Voltage Direct Current (HVDC) links are transferring both power and potential contingencies long distances and across the boundaries of Reliability Coordinators. Below is a table of HVDC links of capacity 250 MW and above within the United States, both operational and planned:

<b>Major High Voltage Direct Current Ties</b>								
<b>250MW and Above within United States</b>								
<b>HVDC Link</b>	<b>End 1</b>	<b>Reliability Coordinator End 1</b>	<b>End 2</b>	<b>Reliability Coordinator End 2</b>	<b>Total Length (km)</b>	<b>DC Voltage (kV)</b>	<b>Power (MW)</b>	<b>First Year of Service</b>
Tres Amigas Superstation	Clovis, New Mexico	SPP/ERCOT/Peak	Clovis, New Mexico	SPP/ERCOT/Peak	B-to-B	765	5,000*	2016
Pacific DC Intertie	Celilo, OR	Peak Reliability	Sylmar, CA	Peak Reliability	1,362	500	3,800	1970
Plains & Eastern Clean Line	Texas County, OK	SPP	Shelby County, TN	TVA	1,207	600	3,500	2018
Rock Island Clean Line	O'Brien County, IA	MISO	Grunddy County, IL	PJM	805	600	3,500	2017
TransWest Express	Rawlins, WY	Peak Reliability	Las Vegas, NV	Peak Reliability	1,167	600	3,000	2015
Intermountain Power Project	Intermountain, UT	Peak Reliability	Adelanto, CA	Peak Reliability	785	500	2,400	1986
Phase II	Radisson, QC	Hydro Quebec, TE	Ayer, MA	ISO New England	1,480	450	2,000	1991
CU (Great River Energy HVDC)	Underwood, ND	MISO	Rockford, MN	MISO	687	400	1,000	1979
Neptune Cable (Long Island)	Hicksville NY	NY ISO	Sayreville, NJ	PJM	105	500	660	2007
Hudson Transmission Project	Bergen County, NJ	PJM	New York City	NY ISO	10	180	660	2013
Welch HVDC	Titus County, TX	ERCOT	Mount Pleasant, TX	SPP	10	170	600	1995
Square Butte	Center, ND (Young)	MISO	Adolph, MN	MISO	749	250	500	1977
Trans Bay Cable	Pittsburg, CA	Peak Reliability	San Francisco, CA	Peak Reliability	85	200	400	2010
Cross Sound Cable	New Haven, CT	ISO New England	Shoreham, NY	NY ISO	40	150	330	2002
*Tres Amigas is planned for eventual 30 GW capacity.								
Sources: IEEE, ABB, Siemens, Tres Amigas LLC, Wikipedia								

Real-world experience has shown that HVDC links are highly vulnerable to GMD events, because harmonics affect the firing angle of commutators.<sup>19</sup> As the table shows, HVDC links present large contingencies up to 5,000 MW. It is a fallacy to assume that the “wide area view”

<sup>18</sup> The figure of 3,947 MW of ISO-New England resources at risk is the sum of the Phase II HVDC link rated capacity, the Seabrook rated capacity, and 700 MW of reactive power support supplied by the Chester SVC for power imported from New Brunswick.

<sup>19</sup> N. Mohan, V. D. Albertson, T. J. Speak, J. G. Kappenman, M. P. Bahrman, “Effects of Geomagnetically-Induced Currents on HVDC Converter Operations,” *IEEE PAS Transactions*, Vol. PAS-101, November 1982, pp. 4413-4418.

of Reliability Coordinators, as asserted by the Standard Drafting Team, is sufficient to cover HVDC contingencies that are not quantifiably planned in advance. It is also a fallacy to assume that failures of bi-pole HVDC links will occur independently at different times, allowing contingency planning for only half of the capacity; experience with the Phase II tie shows that both poles can fail during the same solar storm. It is arbitrary to exclude networks operating between 100 kV and 200 kV from contingency planning because critical equipment can operate between these voltages, as the examples of the 600 MW Welch HVDC tie, 660 MW Hudson Transmission Project, and 330 MW Cross Sound Cable show. The trend of high capacity, long distance HVDC links is accelerating as more renewable generation is transported long distances.

In summary, prudent GMD Operating Procedures should require quantifiable planning for contingencies and this planning cannot be assumed on a voluntary basis. The FERC Commissioners should remand Standard EOP-010-1 for lack of a mandatory requirement for quantified contingency planning and arbitrary exclusion of networks with vulnerable equipment.

### **Adverse Impact of Standard EOP-010-1 on Competition**

FERC Order 672<sup>20</sup> established that a mandatory Reliability Standard should not reflect “the lowest common denominator,” and should have no undue effect on competition. Moreover, the Commission established that it will not defer to the ERO with respect to a Reliability Standard's effect on competition. The Commission rejected the notion that an ANSI-certified process automatically satisfies the statutory standard of review for discriminatory impact or negative effect on competition. The relevant paragraphs from Order 672 are quoted below:

29. A mandatory Reliability Standard should not reflect the “lowest common denominator” in order to achieve a consensus among participants in the ERO's Reliability Standard development process. Thus, the Commission will carefully review each Reliability Standard submitted and, where appropriate, *remand an inadequate Reliability Standard to ensure that it protects reliability, has no undue adverse effect on competition,*

---

<sup>20</sup> FERC Statutes and Regulations, Rules Concerning Certification of the Electric Reliability Organization; and Procedures for the Establishment, Approval, and Enforcement of Electric Reliability Standards, Order No. 672, February 17, 2006, Docket No. RM05-30-000.

and can be enforced in a clear and even-handed manner. Further, the Final Rule allows the Commission to set a deadline for the ERO to submit a proposed Reliability Standard to the Commission to ensure that the ERO will revise in a timely manner a proposed Reliability Standard that is not acceptable to the Commission. These provisions, as well, will strengthen the ERO and Regional Entities by providing mechanisms to achieve effective and fair Reliability Standards.

40. The Commission may approve a proposed Reliability Standard (or modification to a Reliability Standard) if it determines that it is just, reasonable, not unduly discriminatory or preferential, and in the public interest. In its review, the Commission will give due weight to the technical expertise of the ERO or a Regional Entity organized on an Interconnection-wide basis with respect to a proposed Reliability Standard to be applicable within that Interconnection. *However, the Commission will not defer to the ERO or a Regional Entity with respect to a Reliability Standard's effect on competition.*

332. *As directed by Section 215 of the FPA, the Commission itself will give special attention to the effect of a proposed Reliability Standard on competition.* The ERO should attempt to develop a proposed Reliability Standard that has no undue negative effect on competition. Among other possible considerations, a proposed Reliability Standard should not unreasonably restrict available transmission capability on the Bulk-Power System.

338. We reject the notion that we should presume that a proposed Reliability Standard developed through an ANSI-certified process automatically satisfies the statutory standard of review. In this regard, *we agree with EEI and others that the development of a Reliability Standard through the ERO's stakeholder process is no guarantee that a proposed Reliability Standard does not have a discriminatory impact or negative effect on competition* even if the proposal meets its technical or operational objective beyond any restriction necessary for reliability and should not limit use of the Bulk-Power System in an unduly preferential manner. It should not create an undue advantage for one competitor over another.

(Italics added.)

We demonstrate below that Standard EOP-010-1, as an empty and “lowest common denominator” standard, has an adverse effect on competition and is therefore against the public interest. Analysis of three potential situations for regulation of GMD vulnerability and protection expose the clear anti-competitive nature of this standard:

**Situation 1: Current Situation of No Reliability Standards for GMD**

With no reliability standard for GMD, there is limited recovery under tariffs for cost incurred while downrating transmission lines and transformers during solar storms. Operators that prudently downrate incur higher immediate costs. Operators that do not downrate externalize costs and risks to the larger society, but may ultimately be held liable under theories of gross negligence. Prudent operators are placed at an immediate pricing disadvantage with respect to imprudent operators. Incentives for grid operators to provide consistently reliable and available electricity production are low because potential economic losses due to blackout are externalized and incurred by the public and ultimately by utility customers.

**Situation 2: Standard EOP-010-1 with “Requirements and Measures” That Lack Required Mitigative Actions**

When mandatory mitigative actions are not specified in a Reliability Standard, there is limited recovery under tariffs for cost incurred while downrating transmission lines and transformers during solar storms. Operators that prudently downrate or otherwise protect their systems during GMD events incur higher immediate costs. Operators that do not downrate or otherwise protect their systems externalize probabilistic costs of blackout to the larger society, and may also escape liability under theories of gross negligence, because the operators followed a federally-approved Reliability Standard, however ineffective it may be. Prudent operators are placed at an immediate pricing disadvantage with respect to imprudent operators. Moreover, imprudent operators may ultimately escape liability were a GMD-induced blackout to occur. Financial incentives for grid operators to provide reliable and available electricity production are reduced as compared to no reliability standard at all.

**Situation 3: Remanded Reliability Standard with “Requirements and Measures” That Have Required and Effective Mitigative Actions**

When mandatory mitigative actions are specified in a Reliability Standard, there should be recovery under tariffs for cost incurred while downrating transmission lines and transformers during solar storms. Operators that prudently downrate or otherwise protect their systems incur no pricing disadvantage. Operators that do not downrate or otherwise protect their

systems may be fined for non-compliance and may also incur liability under theories of gross negligence due to violation of a federally-approved Reliability Standard. Financial incentives for grid operators to provide consistently reliable and available electricity production increase. The risk of blackout is reduced, also reducing potential economic losses externalized to the public.

### **Preferences for Certain Generator Operators**

Under the current regulatory regime—without any standard for GMD protection—certain Generator Operators are more exposed to liability. Namely, nuclear plant operators have greater vulnerability to GMD because they are more often near coastlines and/or salt water bodies that produce greater GIC. Moreover, nuclear plant operators more often use high voltage, high capacity, single phase GSU transformers with lower winding and transmission line resistance which combine to produce greater GIC flows.<sup>21</sup> The financial impacts of nuclear plant operators' current liability with no GMD reliability standard may include:

- Monetary damages under theories of gross negligence were a GMD event to result in economic damage, loss of life, core meltdowns, and/or radiation release
- Lower stock prices and higher cost of capital should nuclear plant vulnerability to GMD and operators' potential liability become widely recognized

Given their current financial disadvantage, nuclear plant operators, as Generator Operators, might have substantial incentive to promote a GMD reliability standard that would apply to other NERC Functional Entities but not to Generator Operators. In the event of a GMD-induced outage, nuclear plant operators could claim no specific responsibility and thereby might avoid liability under theory of gross negligence. In fact, Standard EOP-010-1 as drafted places no responsibility on Generator Operators, including nuclear plant operators.

---

<sup>21</sup> As noted in "Geomagnetic Storms and Their Impacts on the U.S. Power Grid," (see pages A2-2 to A2-8) even during the moderate Hydro-Quebec storm of March 1989, there were GMD impacts reported at the Calvert Cliffs, Connecticut Yankee, Maine Yankee, Millstone, Peach Bottom, Point Beach, and Vermont Yankee nuclear plants, in addition to outright failure of a GSU transformer at the Salem 1 nuclear plant in New Jersey. If the Nuclear Regulatory Commission orders pre-emptive shutdown of nuclear plants on 4 hour warning of a severe solar storm—as proposed by an NRC witness at the FERC Reliability Technical Conference on April 30, 2012—or orders scrambling of plants on 15 minute warning, risks of capacity shortfalls, voltage instabilities, and cascading failures increase further.

In summary, Standard EOP-010-1 as drafted has discriminatory impact among NERC Functional Entities and negative effect on competition. The Commissioners should remand the standard to include “Requirements and Measures” with mandatory and effective mitigative actions, including mandatory responsibilities for Generator Operators.

### **Alternative Presidential Action to Protect Against GMD**

The facts presented above show that self-determined and largely voluntary GMD Operating Procedures, as proposed in Standard EOP-010-1, would not protect the United States against long-term and widespread electric grid outage. Moreover, multiple official U.S. Government reports, including FERC’s own study conducted by Oak Ridge National Laboratory, show that a severe solar storm could cause permanent damage to hard-to-replace Extra High Voltage (EHV) transformers and generator components such as rotors, stators, and turbine blades. However, under existing legal authority, the President could order preemptive shutdown and protection of the majority of electric generation.<sup>22</sup>

Because of existing legal authority, it is not necessary for the FERC Commissioners to give in to NERC’s defective reliability standard. Indeed, no standard at all, combined with the alternative of Presidential action, would be preferable to Standard EOP-010-1 in its unremanded state.

The best outcome for the public interest would be a reliability standard that recognizes partial power reductions and other halfway measures may not protect the Bulk Electric System from severe solar storms of magnitude comparable to the Carrington Event and also recognizes that grid operators will be reluctant to engage in load shedding on their own initiative. A reliability standard could explicitly pre-coordinate communication channels and procedures whereby a Presidential generator shutdown and transformer de-energizing order could be executed.<sup>23</sup> In order for procedures to be effective, Generator Operators with vulnerable GSU transformers

---

<sup>22</sup> For more information, see “Legal Authority for the President of the United States to Order Interruption of U.S. Electric Generation and Related Electric Grid Protections during a Severe Solar Geomagnetic Storm” in Appendix 3.

<sup>23</sup> For an overview of potential President de-energizing of long-replacement-time but unprotected equipment essential to reliable operation of the bulk power system, see the Foundation Letter to the President of June 28, 2013 and associated Appendices to that Letter, herewith attached to these Comments.

must be included in any reliability standard. We encourage the Commissioners to remand Standard EOP-010-1 with the suggestion that provision for the execution of a Presidential shutdown order be included.

## **Defect in the NERC Standard Approval Process**

The independent trustees of NERC have a fiduciary duty to have public consideration of the merits and shortfalls of standards before approval. We brought forth the defects of Standard EOP-010-1 to the NERC Board of Trustees and specifically asked for public consideration at their November 7, 2013 meeting under “Agenda Item 8a—Geomagnetic Disturbance Mitigation—EOP-010-1.” Nonetheless, no substantive public discussion occurred at the November 7 meeting and, as a result, the public was deprived of its right for due process under Section 215 of the Federal Power Act. See our letter to the NERC Board of Trustees in Appendix 2.

## **Request for Public Hearing**

Given the substantive issues raised in this comment, we respectfully request that the Commissioners hold a public hearing on Standard EOP-010-1. Witnesses for the hearing could include:

- Chair of the NERC Standards Committee;
- CEO of NERC;
- Chair of NERC Board of Trustees;
- Heads of Planning and Operations for Reliability Coordinators exposed to GMD;
- Dr. William Murtagh of the NOAA Space Weather Prediction Center on the risks of a CME comparable to the CME of July 23-24, 2012;
- Representatives of state legislatures, e.g. the State of Maine, that could be obstructed from developing local remedies due to ineffective GMD operating procedures set by NERC and approved by FERC; and
- Advocates for standards that increase marketplace competition for reliable and available electric service.

Questions asked of the witnesses could include:

1. Given the low cost of GIC monitors and the obvious benefit of GIC monitors in conducting effective operating procedures, why does Standard EOP-010-1 not include mandatory installation of GIC monitors at GSU transformers and transmission substations and mandatory reporting of GIC data to Reliability Coordinators, Balancing Authorities, Transmission Operators, and the U.S. Department of Energy's Energy Operations Center?
2. Despite development by NERC's own GMD Task Force of specific actions for GMD Operating Procedures for Transmission Operators, why were none of these actions included in Standard EOP-010-1?
3. While NERC's own GMD Task Force developed a template for GMD Operating Procedures for Generator Operators, why were Generator Operators exempted from any mandatory participation in Standard EOP-010-1?
4. While Balancing Authorities have responsibilities for day-to-day operating procedures under the NERC Functional Model, why are Balancing Authorities exempted from mandatory participation in GMD Operating Procedures under Standard EOP-010-1?
5. Given a GMD warning time of as little as 15 minutes, is it operationally realistic to expect Reliability Coordinators to communicate with hundreds of vulnerable Generator Operators proposing inconsistent actions, especially considering that Generator Operators are exempted from developing their own GMD Operating Procedures and are apparently precluded from initiating mitigation actions on their own?
6. How did the NERC Standards Development Team reconcile real-world GMD impacts on portions of the Bulk Electric System between 100 kV and 200 kV with its whitepaper proposing categorical exemption of this portion of the bulk power system?
7. How did the NERC Board of Trustees determine that Standard EOP-010-1 was appropriate for the public interest without any public discussion? Did the NERC Board of Trustees, or a significant proportion of the Trustees, meet privately to discuss Standard EOP-010-1?

## Conclusion

The substantive facts and potential anti-competitive practices illuminated in this comment show that Standard EOP-010-1 is defectively drafted and will not protect the safety of the public or the public interest, except by voluntary and perhaps impermissible action of electric utilities outside of the four corners of the standard. NERC was once a voluntary standard-setting organization, but as designated Electric Reliability Organization it has a duty to propose standards with mandatory requirements. Unfortunately, with Standard EOP-010-1 NERC has failed in its duty to the public.

Under both the legislative standards of Section 215 of the Federal Power Act and under the principles for standard setting adopted by FERC in Order No. 672, this proposed standard is contrary to the public interest, an operational impediment to improved grid reliability, and a legal shield for anti-competitive behavior.

The interests of the public have not been represented in the NERC process. Most particularly, the purportedly independent NERC Board of Trustees failed in its fiduciary duty to publicly consider well-grounded objections to Standard EOP-010-1 before unanimous approval. A partial remedy would be to hold a FERC hearing where the Chair of the NERC Standards Committee, CEO of NERC, and Chair of NERC Board of Trustees would be called as witnesses, together with other witnesses who advocate more effective and pro-competition standards. Such a hearing could publicly expose the defects of Standard EOP-010-1 and give further legal basis for remand.

FERC's own co-sponsored study has concluded that a severe solar storm could leave 130 million Americans without electricity for 1-2 years. A previous study by the Congressional Electromagnetic Pulse Commission reached a similar conclusion.<sup>24</sup> Accordingly, Standard EOP-010-1 requires remedial attention from the FERC Commissioners and staff. It is essential that the FERC Commissioners, exercise existing authority under Section 215 of the Federal Power

---

<sup>24</sup> For more information about the work of the Congressional Electromagnetic Pulse Commission, see our June 28, 2013 Letter to the President in Appendix 4.

Act and remand Standard EOP-010-1 with a specific deadline for resubmittal of a modified standard that includes: mandatory participation by Balancing Authorities and by Generator Operators; inclusion of networks and essential reactive power equipment operating between 100 kV and 200 kV; and acceleration of a mandatory real-time equipment monitoring and data reporting standard. Only with these reforms will all essential participants in the Bulk Electric System have both data and responsibility to take effective action. Only with these changes can a standard be promulgated that is not anti-competitive, and further, that encourages owners and operators to develop higher reliability as an essential element of a competitive marketplace.

We assert that no reasonable person could conclude that Standard EOP-010-1 is just, reasonable, not unduly discriminatory or preferential, and in the public interest.

We respectfully ask FERC and its Commissioners to order the remand of Standard EOP-010-1. By ordering a remand with a prompt deadline for resubmission, the Commissioners have an opportunity to signal support for a more reliable and competitive bulk power marketplace.

Respectfully submitted by:

Thomas S. Popik, Chairman,

William R. Harris, Secretary,

Dr. George H. Baker, Director

Ambassador Henry F. Cooper, Director

Dr. William R. Graham, Director, and

for the

**Foundation for Resilient Societies**

52 Technology Way

Nashua, NH 03060-3245

[www.resilientsocieties.org](http://www.resilientsocieties.org)

## Appendix 1

### **Comments of the Foundation for Resilient Societies relating to Proposed Standards for “Operating Procedures” to protect the bulk power system from geomagnetic disturbances. Proposed NERC Standard EOP-010-1**

#### **Comments received by NERC on August 13, 2013**

Foundation for Resilient Societies

William R. Harris

Standards relating to Operating Procedures should apply to high side Transformers of 100 kV or higher. Despite higher resistance, transformers in the 100 kV to 200 kV range contribute a significant proportion of GICs that can destabilize the grid. TJ Overbye et al (2012) estimate less than 60% of total MVAR is captured in New England and Michigan if transmission under 230 kV is excluded from protection. New transformers in the 100 kV to 200 kV range are projected by the Energy Information Administration at about 20% of all new EHV transmission mileage planned for the 2012-2018 period. NERC must include generating entities, because existing studies suffice to demonstrate both vulnerability of GSU transformers operated by Generating entities and need for equipment monitoring at generator stators, and related operating procedures to protect generators in severe geomagnetic storms. GSU Generators are at greater risk than generally recognized. See studies by Legro, Abi-Samra and Tesche at ORNL (1985); Walling & Kahn (1991); J G Kappenman, Storm Analysis Report R-112, section 8 (2011); and Luis Marti, "Generator Thermal Stress during a Geomagnetic Disturbance" (2013). Of critical importance, the President of the United States has existing legal authority to order the de-energizing of electric generating facilities that are oil or gas-fired if an emergency so requires. To utilize this authority upon confirmed space warning of a severe solar geomagnetic storm, it is essential that all generating entities serving the bulk power system be included in emergency operating procedure standards; their personnel be trained to validate and confirm de-energizing orders and procedures (and re-energizing procedures), with a multi-day strategic warning but only tens of minutes for tactical order, validation, and execution. Because most of the generating facilities serving the bulk power system are not now equipped with protective equipment that would enable these facilities to "operate through" a severe solar geomagnetic storm, it is essential that generating entities be included in the Operating Procedure coverage and standards. Further, the Nuclear Regulatory Commission has existing authority to order de-energizing and safe shutdown of the 102 NRC licensed nuclear power plants in the U.S. or a subset that are especially affected by a particular GMD event. Generating entities may need to review operating procedure options for rapid shutdown of generators if GSU transformers are

not equipped with protective hardware. Beyond the practical necessity of including transformers and transmission equipment in the 100 kV to 200 kV range, FERC Order 779 applies to the entire bulk power system, which is now defined as commencing at 100 kV or above and not 200 kV or above. It would be illegal for NERC to exclude a significant proportion of the transmission line mileage (for many utilities more than half total EHV transmission mileage). Even if EHV transformers above 200 kV are later protected with neutral ground blocking equipment, leakage of GICs from lower voltage equipment will add significant Mvar into regional grids. FERC intended standards to protect the entire bulk power system of 100 kV or higher; NERC's participating entities should respect and support this federal policy.

Reason: Earlier comments on the Operating Procedure Templates submitted by the Foundation for Resilient Societies were ignored, and not addressed on their merits by the GMD Task Force management and by the NERC Planning Committee. See our previous comments at: [https://resilientsocieties.org/images/Comments Operating Procedure Template NERC GMDTF Phase 2 Rev1.pdf](https://resilientsocieties.org/images/Comments%20Operating%20Procedure%20Template%20NERC%20GMDTF%20Phase%20Rev1.pdf).

The Foundation for Resilient Societies has concerns that the NERC Planning Application Guide, developed without full public access to the related model assumptions, will mis-characterize geomagnetic latitudes with geographic latitudes; and will result in scientifically invalid assumptions that the NERC modeled "operating procedures" will suffice without need for hardware protections. For our Foundation review of the Draft NERC GMD Planning Application Guide, our review dated August 9, 2013, see: [http://resilientsocieties.org/images/Resilient\\_Societies\\_Comments\\_on\\_GMD\\_Planning\\_Application\\_Guide\\_Final.pdf](http://resilientsocieties.org/images/Resilient_Societies_Comments_on_GMD_Planning_Application_Guide_Final.pdf).

For effective operating procedures implemented through regional balancing authorities, improved near-real-time GIC monitoring will be needed for all GSU transformers, SVC equipment, and major generating equipment at risk in severe solar storms. Regional balancing authorities will require improved near-real-time monitoring to prepare and protect ready reserves. Communications must be designed to operate even during severe solar storms. Regional balancing authorities will need to be in contact with the White House Situation Room and federal command centers elsewhere.

For concerns of the Foundation for Resilient Societies, see our website at [www.resilientsocieties.org](http://www.resilientsocieties.org). A case study of Maine and ISO-New England utilizing recently revised operating procedures documents our concern that regional "ready reserves" in a severe geomagnetic storm are likely to be inadequate due to a combination of vulnerable long distance HVDC transmission lines, a record of SVC "trips" during only moderate solar storms, and unprotected generating equipment in New England, where high GICs are recorded.

**Comments received by NERC on October 23, 2013**

Foundation for Resilient Societies

William R. Harris

No Question 1: Our Foundation's Case Study on Maine and ISO New England's capacity to mitigate a severe solar geomagnetic storm (March 2013 - found on website [www.resilientsocieties.org](http://www.resilientsocieties.org)) reaffirmed our prior understanding that the Regional Coordinators (in this case ISO-New England) cannot adequately coordinate "operating procedures" to mitigate a severe GMD event without concurrent jurisdiction over Balancing Authorities (BAs) and Generator Operators (GOs). In a severe solar storm, the combination of generation reserves together with demand response reserves may not enable Regional Coordinators (RCs) to balance loads without active preparation and support of balancing authorities. For ISO-New England that would include Canadian resources and balancing operators beyond the authority and scope of FERC Order No. 779. In effect, the various balancing (BAL) standards do not include standards for emergency hydroelectric generation or protection of equipment, such as series capacitors and static VAR compensators (SVC), necessary to maintain voltage stability for power imported from Canada. Without power imported from Balancing Authorities outside of ISO-New England, which also may be at risk of concurrent Geomagnetically-Induced Current (GIC), reactive power consumption, and adverse harmonics, the New England region is more likely to be at risk of prolonged electric grid blackout. The rationale of NERC's drafting team for excluding Balancing Authorities from participation as responsible entities to fulfill "operating procedures" is stated in NERC's "Functional Entity Applicability" document, which states: "... Balancing Authorities (BA) should not be among the applicable functional elements because there were no additional steps or tasks for a BA to perform beyond their normal balancing functions to mitigate GMD events." To the contrary, as GIC equipment monitors are already deployed within some Balancing Authorities, BA's need to assess the performance and GMD-related deterioration of networks during the moderate solar geomagnetic storms in coming years. Balancing Authorities may benefit from modeling balancing options under degraded conditions, such as the loss of a key Static VAR Compensator. There are interplays between selection of equipment options, and selection of balancing strategies to "operate through" moderate level solar storms. Further, commercially available GIC monitors now provide "operating procedure" choices for their programming. At what level should different alarms be set, and to which entity should these alarms be reported? BAs have a "need to know" and critical roles to play, in both advising about equipment upgrades and in making best use of, or de-energizing as needed equipment that impacts the ability to balance loads before, during and after a GMD event. For further information on GIC monitors that are now available, see the

Foundation Comments of October 15, 2013 in Maine PUC Docket 2013-00415. Moreover, if the Balancing Authorities are full-time partners in "operating procedures" to be coordinated by the RCs, it is more likely that additional GIC monitors will be installed at key locations, and critical equipment such as SVCs, Extra High Voltage (EHV) transformers, and generators will be protected from tripping or permanent damage. Also, power transmission over High Voltage Direct Current (HVDC) ties that are vulnerable to tripping from GIC will be better planned and protected. Already in New England, the Phase II HVDC tie from Canada has tripped off during a solar storm. A second concern of our Foundation relates to the arbitrary limitation of equipment to be subject to "operating procedures" to those portions of utility networks with high-side voltage of 200 kV or higher. We understand that the lower voltage transformers have higher resistance; hence they are generally less susceptible to GIC entering the bulk power system. But there are so many more transformers under 200 kV--roughly double the total transmission mileage in the U.S. transmission infrastructure--and so many more opportunities for "GIC leakage" into the EHV transmission networks. It appears imprudent to exclude transformers in the 100 kV to 200 kV range from "operating procedures." PowerWorld has estimated that less than 60% of total MVAR enters the bulk power system through transformers at 230 kV or higher, in both New England and in Michigan. Other regions that have not been adequately modeled to date may also incur high "GIC leakage" from transformers with high-end voltage under 200 kV. Transformers supplying these additional MVARs may experience transmission congestion, adverse effects of harmonics through overheating and equipment vibration, and risks of equipment damage or total loss. The economics of "operating procedures" may well demonstrate benefits of some combination of equipment installation and operating procedures to reduce the rate of "GIC leakage" into the bulk power system via transmission sub-systems operating below 200 kV. NERC has not done the financial analysis mandated by FERC Order No. 779, so NERC should not prematurely exclude these grid pathways subject to GMD-induced instability, unreliability, and reduced capacity utilization. It is also notable that much of the specialized equipment designed to provide reactive power or to stabilize voltages within design tolerances operate below 200 kV. Is this equipment to be excluded from protective "operating procedures" under Proposed NERC Standard EOP-010-1? Siemens, for example, identifies many Static VAR Compensators operating at less than 200 kV. CenterPoint's Crosby SVC (IOC 2008) operates at 138 kV. Brushy Hill (1986, Canada) operates at 138 kV. Entergy's Porter SVC in Texas (IOC 2005) operates at 138 kV. CenterPoint Energy's Bellaire (IOC 2008) operates at 138 kV; Exelon's 2 SVCs at Elmhurst operate at 138 kV. Entergy's Prospects Heights SVC near Chicago has 2 SVCs at 138 kV. Northeast's Glenbrook, CT STATCOM operates at 115 kV. In "Appendix 2, Detailed Summary of Power System Impacts from March 13-14, 1989 Geomagnetic Superstorm" of "Meta-R-319, Geomagnetic Storms and Their Impacts on the U.S. Power Grid" by John Kappenman (January 2010, Oak Ridge National Laboratory), a table of system impacts on Page A2-2 shows no less

than 10 GIC impacts on equipment operating at a base voltage of less than 200 kV. This is real - world data during a moderate solar storm. In contrast, NERC offers only theorizing in its document, "Network Applicability, Project 2013-03 (Geomagnetic Disturbance Mitigation), EOP-010-1 (Geomagnetic Disturbance Operations), Summary Determination" that networks operating at less than 200 kV would not be affected by GIC. Real world data should trump the technical speculation of NERC. Networks operating at less 200 kV (and over 100 kV) are part of the Bulk Power System and should be included in standards for GMD mitigation. Increasingly, the Bulk Power System is connected to wind power generation, with many wind power systems at ocean boundaries that may import above-average GIC. Wind power systems are generally stepped up to less than 200 kV. Wind power transmission systems are increasingly outfitted with GIC monitors. So, if these facilities are excluded from "operating procedures," will that mean that the near-real-time GIC data now available to wind power operators will not be shared with the RCs? It is notable that in the Maine PUC Docket 2013-00415, with documents retrievable via the Internet, John Kappenman of Storm Analysis Consultants reported in October 2013 that, depending upon the orientation of a solar storm, the single GIC monitor at Chester Maine might report little or no GIC, even in a large solar storm. This is the only near-real-time GIC data received by ISO-New England, the relevant RC. Why would NERC seek to exclude GIC monitors at wind generation-transmission interconnections below 200 kV from "operating procedure" management by the Regional Coordinators? This would appear to be imprudent and is likely to result in needless risks to bulk power system reliability. In FERC Order No. 777, 142 FERC Para 61,208, issued on March 31, 2013, FERC provided a rationale for extending a reliability standard below 200 kV voltages under circumstances where the assets under consideration "are critical to reliability." See FERC Order No. 777 at p. 23, in Docket RM12-4-000. All of the SVCs, STATCOMs, series capacitors, and prospective dynamic VAR compensators with voltage under 200 kV should be considered as equipment "critical to reliability" for purposes of GMD operating procedures. Finally, our Foundation is alarmed that Generator Operators are now excluded from "operating procedure" jurisdiction in the proposed standard. Why? The NERC Drafting Team determined "that Generator Operators should not be among the applicable functional entities because any operating procedure to mitigate the effects of GMD would need to be supported by an equipment-specific study and is expected to require GMD monitoring equipment." We find these rationales to be implausible. Generator Operators have, for more than a decade, utilized formulae provided (by ABB and other vendors) to down-power generation, hence loads on unprotected EHV transformers. There is operating experience with these "down-powering" practices that need to be shared as "best practices" or unacceptable practices. Those Generator Operators that already have installed GIC monitors, working with regional models, have already produced estimated of field voltages that will or will not collapse regional transmission networks. It would be imprudent to wait until every Generator Operators has GIC monitors at every GSU transformer to develop "operating

procedures” that can protect critical equipment using cost-effective strategies. Another reason to bring Generator Operators into “operating procedure” practices as soon as possible is to help educate Generator Operators to understand the practical limits of “operating procedures” for Generator Operators with equipment running at “GIC hotspots.” Neutral ground blocking devices not only eliminate virtually all GICs entering GSU transformer, but also reduce vulnerabilities of other GSU transformers that are unprotected within regional networks. The sooner executives of Generator Operators learn whether they will benefit from hardware protecting investments, the better. See the Foundation’s reproduction of a NOAA (Denver) initiative to display the frequency of half-cycle solar GMD events for the period 1958-2007 (Figure 20), indicating an above average risk in the years following solar maxima. The last solar maximum occurred in September 2013. See the Foundation Reply Comment of October 15, 2013 in Maine PUC Docket 2013-00415. FERC’s Order No. 779 seeks expedited protection of the bulk power system, not endless delays of needed protections. Many Generator Operators own and operate GSU transformers that at risk for damage due to GICs entering their GSU transformers and the bulk power system. Some Generator Operators, e.g. NextEra, have spun-off subsidiaries that can qualify their EHV transformers for OATTS cost-recovery by transferring ownership into a closely held transmission company. In either case, Generator Operators are key players in determining whether to downpower during a space weather-warning period. Many Generator Operators are also aware that the harmonics from GICs that enter their systems cause both overheating and vibrational effects on other equipment such as: generator stators, stator cooling pipes, and generator turbines. To exclude Generation Operators from "operating procedures" appears unfounded and a possible aggravating factor in a severe solar geomagnetic storm. Lastly, NERC needs to address what can be done to protect high-cost, long-replacement-time equipment during a severe solar storm, such as the New York Railroad storm of May 1921. Will the Nuclear Regulatory Commission preemptively order the de-energizing of all nuclear generating facilities and associated GSU transformers? Should the President order the de-energizing of all unprotected GSU transformers, including those without neutral ground blocking or designs projected to survive impending GMD events? If so, how will the Generator Operators protect their equipment, train personnel to validate and authenticate de-energization orders, and plan for optimal "black start" procedures? Excluding Generation Operators from the jurisdictional scope of "operating procedures" appears to be based on the convenient but false assumption that the only solar geomagnetic storms for which electric utilities need prepare are those of moderate strength and short duration. We cannot in good conscience vote "yes" for a proposed standard for "operating procedures" that excludes Balancing Authorities, excludes Generator Operators, excludes critical equipment operating at under 200 kV, and excludes operators of GIC monitoring equipment from a mandate to share safety-related information in near-real time. NERC and the electric utility industry can achieve

more effective standards. If this standard is approved by NERC as proposed, FERC should require key modifications in its review process.

For further background information on the Foundation's support of wider jurisdiction for coordinated "operating procedures" see our March 2013 case study of Maine and ISO-New England in a solar geomagnetic storm, found at [www.resilientsocieties.org](http://www.resilientsocieties.org) and the Foundation's comments responsive to queries by the Maine Public Utilities Commission, in MPUC Docket 2013-00415 (Oct 4, 2013), and our Supplemental and Reply Comments in that same Docket (October 15, 2013).

## Appendix 2

### Foundation for Resilient Societies

52 Technology Way

Nashua NH 03060

[www.resilientsocieties.org](http://www.resilientsocieties.org)

November 1, 2013

Frederick W. Gorbet, Chair

Janice B. Case, Vice Chair

Paul F. Barber

Robert G. Clarke

Gerry W. Cauley

David Goulding

Board of Trustees

North American Electric Reliability Corporation

3353 Peachtree Road, N.E. Suite 600, North Tower

Atlanta, GA 30326

Douglas Jaeger

Kenneth G. Peterson

Bruce A. Scherr

Jan Schori

Roy Thilly

Dear Trustees:

Scheduled for your November 7th Board of Trustees meeting is “Agenda Item 8a—Geomagnetic Disturbance Mitigation—EOP-010-1.” We urge you to vote “no” on approval of this standard and to send the standard back to the NERC Standards Committee. The standard should be promptly redrafted to include Balancing Authorities, Generator Operators, and Transmission Operators having transformers with high side voltage at 100 kV and higher.

Standard EOP-010-1 was drafted in response to Order 779 of the Federal Energy Regulatory Commission (FERC) for a standard for operating procedures to protect the Bulk Power System against Geomagnetic Disturbance (GMD). The standard, as drafted, is technically inadequate, cost ineffective, and will not protect the American public for the following reasons:

1. While the FERC-approved Bulk Electric System definition includes transmission at voltages at 100kV and above, and while multiple GMD impacts on Static VAR Compensators and other equipment operating between 100kV and 200kV were reported by electric utilities during the March 1989 solar storm, Standard EOP-010-1 would exempt Transmission Operators with equipment operating between 100 kV and 200 kV. Transmission Operators operate Static Var Compensators, capacitors, and other equipment designed to provide reactive power and to stabilize transmission networks during GMD. Attached to this letter is a listing of March 13, 1989 storm impacts on critical equipment operating at less than 200 kV. These real-world and non-trivial GMD impacts during a moderate storm with geoelectric fields of only 2 volts/kilometer invalidate the Standard Drafting Team’s summary determination that “The effect of GIC in networks less than 200 kV has negligible impact on the reliability of the interconnected transmission system.” The pseudo-scientific study of the NERC Standard Drafting Team,

“Network Applicability, Project 2013-03, EOP-010-1, Summary Determination” is an example of a report that is consistent with an apparent policy goal of NERC’s membership, but which ignores available scientific evidence.

2. Geomagnetically-Induced Current (GIC) monitors are commercially available and can be installed for as little as \$10,000 each, which is far less than the cost of a technical study to see if a GIC monitor might be required.<sup>1</sup> Nonetheless, Standard EOP-010-1 has no requirement for GIC monitoring or the mandatory sharing of GIC data with Reliability Coordinators and would therefore require Reliability Coordinators to force “blind” operating procedures on Balancing Authorities, Transmission Operators, and Generator Operators, increasing blackout risks to the public and imposing costs on ratepayers due to “off-cost dispatch” of bulk power transmissions.
3. While Generator Step Up (GSU) transformers are a major GMD vulnerability according to a study by the Oak Ridge National Laboratory, “Geomagnetic Storms and Their Impacts on the U.S. Power Grid,” Generator Operators are exempted from specific responsibility in Standard EOP-010-1. In notable contrast, NERC’s own GMD Task Force recognized the vulnerability of GSU transformers and developed a “Geomagnetic Disturbance Operating Procedure Template—Generator Operators” which was formally approved by the Planning Committee in February 2013 and also endorsed by the Operating Committee. The Standard Drafting Team exempts Generator Operators from Standard EOP-010-1 because Generator Operators have no current requirement for GIC monitoring devices and absent GIC data, “the GOP would not have the technical basis for taking steps on its own and would instead take steps based on the RC or TOP’s Operating Plans, Processes, or Procedures.” This convenient rationale is proposed in the NERC document “Functional Entity Applicability, Project 2013-03, EOP-010-1, Summary Determination” and ignores that the lack of required GIC monitoring is completely the result of a defectively drafted standard; see Item 2 above. In essence, the Standard Drafting Team proposes that Generator Operators pay up to \$250,000 for a technical study to see if their equipment might be vulnerable to GIC rather than install a GIC monitor for \$10,000 and find out for sure. The Standard Drafting Team also believes that the real-time responsibilities of Generator Operators under fast-moving GMD conditions are already covered in the NERC Functional Model. In fact, the deficiencies in the NERC Functional Model during GMD conditions are a primary rationale for FERC Order 779.
4. While Balancing Authorities are responsible for scheduling reactive power, spinning reserves, demand response, and other real-time mitigative steps during GMD, these entities are exempted from specific responsibility in Standard EOP-010-1. The Standard Drafting Team believes that the real-time responsibilities of Balancing Authorities under fast-moving GMD conditions are already covered in the NERC Functional Model. In fact, the deficiencies in the NERC Functional Model during GMD conditions are a primary rationale for FERC Order 779.

---

<sup>1</sup> For example, Bonneville Power Administration paid \$253,000 for modeling of GIC in their network.

5. The “Requirements and Measures” in Standard EOP-010-1 are so non-specific that utilities could easily develop paper plans to satisfy the requirements of the standard, but these plans could be ineffective during severe or even moderate solar storms.<sup>2</sup>

For further background on these deficiencies in the standard, please see our comments filed and available in the official record for Standard EOP-010-1 on the NERC web page for “[Project 2013-03 Geomagnetic Disturbance Mitigation](#).”

Any reasonable person would likely conclude that Standard EOP-010-1, as currently drafted, is not compliant with the requirements of FERC Order 779. Moreover, the proposed exemption of networks with high side voltage between 100 kV and 200 kV is not compliant with the requirements of FERC Order 773, which established a “bright line threshold” of 100 kV for the Bulk Electric System.

Oak Ridge National Laboratory estimates that a severe solar storm would interrupt power to as many as 130 million Americans. Accordingly, a reliability standard to prevent a blackout from GMD should deserve the highest level of attention and thoughtful consideration from NERC and its independent trustees. However, past meetings of the NERC Board of Trustees have had only perfunctory discussion about GMD risks to the American public—an example being the trustee meeting that approved the now-discredited NERC report, “2012 Special Reliability Assessment: Effects of Geomagnetic Disturbances on The Bulk Power System.” Instead, the independent trustees have had a practice of quickly and mechanistically moving through numerous agenda items, voting to “approve” on each item.

As independent trustees of NERC, it is your fiduciary duty to have a substantive and public discussion of the merits and shortfalls of Standard EOP-010-1 at your November 7th meeting. Again, we urge you to vote “no” on EOP-010-1, Agenda Item 8a, because this defective standard would not protect the American public from long-term and widespread electric grid outages caused by solar storms.

Sincerely,



Thomas S. Popik  
Chairman, Foundation for Resilient Societies

Attachment: March 13, 1989 Geomagnetic Disturbance Chronology of Reported North American Power Grid Events

cc:

Jon Wellinghoff, Chairman, FERC  
David Morenoff, Acting General Counsel, FERC

---

<sup>2</sup> For an example of GMD operating procedures that would probably meet the requirements of Standard EOP-010-1, but would nonetheless be inadequate, see our study of ISO-New England operating procedures, “Solar Storm Risks for Maine and the New England Electric Grid and Potential Protective Measures” available at: [http://resilientsocieties.org/images/Interim\\_Foundation\\_Report\\_on\\_Maine\\_Solar\\_Storm\\_Risks\\_March\\_19\\_2013.pdf](http://resilientsocieties.org/images/Interim_Foundation_Report_on_Maine_Solar_Storm_Risks_March_19_2013.pdf).

## March 13, 1989 Geomagnetic Disturbance

### Chronology of Reported North American Power Grid Events

Adapted from Pages A2-2 to A2-8 of "Geomagnetic Storms and Their Impacts on the U.S. Power Grid"  
Oak Ridge National Laboratory, January 2010

<b>Event No.</b>	<b>Date</b>	<b>Time (EST)</b>		<b>Area or System</b>	<b>Event</b>	<b>Base kV</b>	<b>Comments</b>
		<b>From</b>	<b>To</b>				
29	3/13/1989	245		Minn. Power	Capacitor	115	Lost capacitor bank at Nashwauk. Neut overcurrent relay
44	3/13/1989	608		Cent. Hud.	Capacitor	69	Pulvers Corners capacitor trip
47	3/13/1989	615		APS	Capacitor	138	7 Capacitors tripped
54	3/13/1989	618		Va. Pwr.	Capacitor	115	Virginia Beach
57	3/13/1989	619		Cent. Hud.	Capacitor	115	Hurley Ave. capacitor trip
94	3/13/1989	1645	2000	WPL	Voltage	138	Various voltage problems. Regulators hunting
100	3/13/1989	1655		Atl. Elec.	Voltage	69	
108	3/13/1989	1658		BPA	Capacitor	115	Tripped by neutral time ground at 4 substations
175	3/13/1989	2017		NEPOOL	Capacitor	115	Orrington capacitors (1, 2, &3) opened and would not close
183	3/13/1989	2020	2030	Atl. Elec.	Voltage	138	
192	3/13/1989	2032		PJM		69	Nazareth Capacitors tripped

## Appendix 3

### Legal Authority for the President of the United States to Order Interruption of U.S. Electric Generation and Related Electric Grid Protections during a Severe Solar Geomagnetic Storm

William R. Harris

The President of the United States holds powers both enumerated and implied by Article II of the U.S. Constitution, and by the President's role as commander-in-chief. Moreover, the Presidential oath of office to "faithfully execute" the laws provides a duty to fulfill a wide array of presidential functions, including the continuity and functionality of the executive branch, aid to the legislative and judicial branches, fulfillment of treaties and other international agreements, and support to state and local governments. Beyond these powers and responsibilities, the President has duties and powers, many of them delegable to Cabinet secretaries, or others.<sup>1</sup> While the police powers are generally reserved to the states (per the 10<sup>th</sup> Amendment to the federal constitution), the President retains powers granted under the U.S. Constitution and under statutory laws.

Severe solar geomagnetic storms fall under the more general category of high impact, low frequency events that could result in the death of millions of Americans and threaten the existence of the United States as a country. Real-world experience during small solar geomagnetic storms shows that current induced by these storms can overheat and otherwise permanently damage extra high voltage (EHV) transformers used for electric grid transmission. Under normal conditions, the lead time for ordering replacement transformers is months to years; additionally, most EHV transformers are manufactured outside of the United States. As a result, any solar geomagnetic disturbance that results in widespread damage of critical grid infrastructure—including but not limited to EHV transformers—could result in a blackout lasting months or even years. Because the electric grid is the keystone infrastructure upon which all other critical infrastructures depend, long-term grid outage is an existential threat.

Unlike other most other natural disasters that affect only a single state, or several adjoining states, a severe solar geomagnetic storm is more likely to affect a region of the United States, the entire continental U.S., or even multiple countries. During a severe solar storm, it is unlikely that states acting alone will be capable of effectively exercising their police power functions for disaster management, whether through a state public utility commission, or a governor's office of emergency management, or other executive authority. Might instead the federal

---

<sup>1</sup> Title 3, section 301 of the U.S. Code provides a general authorization for presidential delegation of functions, excepting specifically non-delegable functions, so long as these acts of delegation are published in the Federal Register. For example, the duty to maintain a domestic industrial base, including national defense resources preparedness, is a delegation by President Obama in March 2012. See 77 FR 16651 (2012).

government retain the power and duty for emergency preparedness? With warnings of a severe solar geomagnetic storm, might the President have the authority and duty to interrupt electric power generation to protect critical electric infrastructures? Without prompt action supported by the express and implied powers of the President, substantial portions of the North American electric grid might not endure, or might not be expeditiously reconstituted after the emergency has passed. Indeed, the United States as a nation might not endure, absent appropriate exercise of Presidential authority.

What are some of the presidential powers or powers delegated by the President or Congress to subordinate executive officers of the federal government? Title 42 U.S.C. sec. 5195 (P.L. 93-288, Title VI, sec. 601) explains as a purpose the provision of “a system of emergency preparedness for the protection of life and property in the United States.” The Federal Government “*shall* provide necessary direction, coordination, and guidance, and *shall* provide necessary assistance as authorized by the subchapter so that a comprehensive emergency preparedness system exists for all hazards.” (Italics added.) A federal preparedness plan and system to cope with *all hazards* is mandatory, not optional.

The Federal government would likely have multiple sources of confirmation of an impending severe geomagnetic storm, beyond the Advance Composition Explorer (ACE) satellite or its prospective replacement satellite: for example, a variety of National Aeronautical and Space Administration (NASA), or National Reconnaissance Office (NRO) space assets or other Department of Defense space assets might independently confirm an impending solar geomagnetic storm. Notably, these are assets of the federal government, not the several states.

How might the President utilize specified emergency powers that complement Article II presidential powers under the U.S. Constitution? Two statutes are of special interest in anticipating and preparing to protect critical electric grid infrastructure before, during, and after a severe solar geomagnetic disturbance.

The first statute is the Carter era International Emergency Economic Powers Act [P.L. 95-223] and its year 2007 enhancements [P.L. 110-96], the International Emergency Economic Powers Act found at 50 U.S.C. § 1701 et seq. Section 1701, enables a President “to deal with an unusual and extraordinary threat, which has its source in whole or substantial part outside the United States” with impacts upon the national security, foreign policy, or the economy.

A coronal mass ejection from the sun, causing severe geomagnetic disturbance and threat to critical national infrastructure, including the bulk power system, would trigger presidential emergency powers. Importantly, with proper exercise of federal authority, the President and his staff could reasonably anticipate scenarios involving the potential loss of electric grid facilities, and plan for temporary protection of key assets. Many of these assets, such as EHV transformers, or static (or dynamic) VAR capacitors, might be protected from irreversible

damage by a presidential order to de-energize key equipment, while allowing an “operate through” regime for other equipment assessed as having a “withstand” capability or shielded by neutral blocking devices.

Emergency plans and related exercises would require a national inventory of critical assets, including identification of those assets most likely to sustain permanent damage if left unprotected. In contrast, generating facilities without long transmission lines, or operating at lower voltages, or operating where soil conditions might provide some protection against *geomagnetically induced currents* could be candidates to “operate through” all but the most severe solar geomagnetic disturbances. Generation facilities and transmission lines protected by “neutral ground blocking equipment” might also “operate through” solar storms. It would be important that the White House Situation Room, national monitoring facilities, and regional electric balancing authorities keep track of which electric grid assets could be designated as “operate through” assets versus those critical assets that are candidates for prompt *de-energizing*. Mere “de-rating” of equipment, so that generators operate at reduced electric loads, may be insufficient to prevent damage, because an energized transformer at near-zero load can still be vulnerable to both overheating hazards and to vibrational stress.

A second federal statute provides the President specific authority to order the de-energizing of energy facilities that utilize natural gas or petroleum “as a primary energy source” for the duration of “a severe energy supply disruption.” This statute, known as the Powerplant and Industrial Fuel Act of 1978 [P.L. 95-620, found at Title 42 U.S.C. § 8374], anticipated the need for the President to halt uses of natural gas or petroleum products during an international oil embargo or more generally “an energy supply disruption.”

The larger purpose of P.L. 95-620 was to preserve a functional U.S. economy and the public health, safety, and welfare despite a threat to sustainable electricity production and availability of fuel supplies for transportation. The specific scenario linked to this legislation, a disruption of imported oil, may no longer be likely, but the specific, literal authorities of the President remain; and these authorities remain useful to cope with a solar geomagnetic disturbance that requires de-energizing critical electric grid equipment.

Under the Powerplant and Industrial Fuel Use Act, if the President declares a severe energy supply interruption, or anticipates this outcome from future confirmed warnings of severe solar geomagnetic storms, per Title 42 U.S.C. section 8374(a), the President may make findings: that a national or regional fuel shortage exists or may exist; that the effect is likely to be of significant scope and duration, and “of an emergency nature.” Thence, the President may by order –

“prohibit any electric powerplant or major fuel-burning installation from using natural gas or petroleum, or both, as a primary energy source for the duration of such [energy supply] disruption.”

The duration of the emergency Presidential order is limited to the lesser of the “duration” of the emergency or 90 days – which should suffice for the several-day duration of previously observed severe solar geomagnetic storms. Under this statute, the President may not delegate authority to issue relevant orders to other federal officials. [42 U.S.C. § 8374(e).]

What might be the operational use of these two statutes? Assuming development of appropriate equipment databases and communication systems that can operate during severe solar storms, the President might – with prior practice exercises and a validation system to confirm presidential orders – cause the immediate shutdown of all unprotected gas-fired and petroleum-fired electric generation facilities within the bulk power system of the United States.

U.S. Energy Information Administration projections for year 2013 U.S. electric generation, by fuel type, estimate natural-gas electric generation as 27.6% of the annual total, and petroleum at just 0.6% of the annual total, or a combined share of about 28.2% of total electric generation.<sup>2</sup>

Concurrently, the Nuclear Regulatory Commission (NRC) has existing authority to de-energize all 102-licensed nuclear power plants operating under its supervision.<sup>3</sup> Temporary plant shutdown is done routinely during earthquakes and hurricanes under NRC safety authority. At the April 30, 2012 FERC Technical Conference on geomagnetic disturbances and reliability of the bulk power system<sup>4</sup>, an NRC nuclear engineer testified that the prudent course of action before a severe solar geomagnetic storm might be to shut down all NRC licensed power reactors. But since these facilities produce about 18-19% percent of national electric supply, their uncoordinated shutdown would by itself produce a risk of electric grid instability.

With combination of the President’s non-delegable authority to de-energize natural gas and petroleum fired generating facilities, and the NRC’s authority to de-energize 18-19% percent of projected U.S electric generation, generating facilities that will produce about 46-47% of total U.S. electric generation can be protected – either by de-energizing orders or by “operate through” instructions.

In a severe solar storm, might the United States be able to protect a higher share of its critical electric infrastructure than merely 46-47% of annual generating capacity? The largest single

---

<sup>2</sup> See U.S. Energy Information Administration, “Short-Term Energy Outlook,” June 2013.

<sup>3</sup> The two San Onofre (SONGS) power plants in Southern California are now inoperable and scheduled for decommissioning.

<sup>4</sup> See FERC Docket AD12-13-000 (2012).

source of U.S. electric generation, by fuel type, remains coal. The U.S. Energy Information Administration estimates that coal-fired electric generation will remain just above 40% of total U.S. electric generation in years 2013 and 2014.<sup>5</sup>

The President cannot rely upon the Powerplant and Industrial Fuel Use Act of 1978 to de-energize coal-fired power plants because that Act specifically authorizes restrictions on natural gas and petroleum fuels but not coal. It was assumed, in 1978, that coal-fired electric generation would be increased during an energy supply disruption.

Might the President order de-energizing of coal-fired plants before or during an impending solar storm by declaring a national emergency under the International Emergency Economic Powers Act [50 U.S.C. §1701 et seq.], or under the Defense Production Act of 1950 as amended, or under the doctrine of “necessity”?<sup>6</sup> Under our interpretation, the President has these emergency powers, and exercise of these powers in anticipation of a severe solar geomagnetic storm could preserve critical electric grid equipment. Moreover, if actionable intelligence were sufficiently precise, the President could order the de-energizing of all critical but unprotected electric grid equipment in anticipation of a man-made electromagnetic pulse (EMP) attack.

In substance and in law, the President does have emergency powers to order the de-energizing of coal-fired electric generation during a solar geomagnetic storm emergency. However, without express legislative authority—specifically legislation that reverses the implied prohibition of Presidential authorization to de-energize coal-fired electric generation facilities—the federal government might be liable under the U.S. Constitution for the uncompensated “taking” of private property.<sup>7</sup> The Constitutional obligations of the federal government are not waived merely because of the necessity of action.<sup>8</sup> If the President acts to de-energize a regional electric grid or the national electric grid, or if the President declines to act, and the

---

<sup>5</sup> See U.S. Energy Information Administration, “Short-Term Energy Outlook, June 2013.”

<sup>6</sup> Thomas Jefferson wrote of “the unwritten laws of necessity, of self-preservation, and of the public safety, control the written laws....” Letter, Thomas Jefferson to John Colvin, Sept. 20, 1810, in 11 The works of Thomas Jefferson at 146 (Paul Leicester Ford, ed. 1905). Before adoption of the U.S. Constitution, Alexander Hamilton wrote in The Federalist No. 23, “[T]he circumstances which may affect the public safety are [not] reducible within certain determinate limits... there can be no limitation of that authority which is to provide for the defense and protection of the community, in any matter essential to its efficacy....” (December 18, 1787).

<sup>7</sup> “Private property” under the takings clause could include damage to capital equipment, loss of income for electric utilities, and business interruption losses for utility customers. The issuance of a Presidential Order to de-energize generating facilities may have advantages for utility owners compared to their voluntary decision(s) to de-energize their power plants during a severe solar storm. Under many insurance policies the intentional shutdown of a power plant by an insured owner may void insurance coverage against customer claims and for property damage of insureds.

<sup>8</sup> “The American Constitution contains no general provision authorizing suspension of the normal government processes when an emergency is declared by appropriate government authority.” Quoted from Henry P. Monaghan, “The Protective Power of the President,” 93 Colum. L. Rev. 1 at 33 (1993). For a review of presidential emergency powers when supporting legislation does not exist, and when contradictory legislation is in effect see the concurring opinion of Justice Robert Jackson in Youngstown Sheet & Tube Co. v. Sawyer, 343 U.S. 579 (1952).

nation suffers greater losses of human life and harm to the national economy, most likely the President's actions or inactions would be precluded from federal liability under the "discretionary function exception" to the Federal Tort Claims Act.<sup>9</sup>

The primary reason to seek unambiguous legislative authority for the President to order the de-energizing of the U.S. or a regional electric grid is to avert needless pre-decisional delay. Legal authority should be crystal clear, and known to federal and state officials, and by utility operators and regional electric balancing authorities that might be subject to presidential orders, especially if the window of necessary action involves minutes, not hours. Hence, the more prudent course, in anticipation of a severe solar geomagnetic storm or man-made EMP hazard, might be for the President and his legal advisors to seek a clean legislative authorization from the U.S. Congress: to protect critical electric facilities essential to the bulk power system, the national defense, or other critical national infrastructure; and including the authority to order the de-energizing or re-energizing of the bulk power system of the United States or regional entities served by the bulk power system. Anticipating the risk of widespread electric blackouts during a severe geomagnetic storm, any federal legislation to broaden presidential authority to authorize temporary de-energizing of critical electric power generation might also: provide incentives for "grid islanding" to ensure critical electricity supply to hospitals and nursing homes; to provide for continual electricity supply to critical telecommunications systems; and prioritize off-site power to military facilities and nuclear power plants.<sup>10</sup> A temporary but controlled shutdown of the North American electric grid would lead to loss of life and extraordinary economic damage. But the costs of inaction—including the risk of catastrophic grid collapse—appear to be even higher.

Might a Bill introduced in June 2012 in the U.S. House of Representatives, H.R. 2417, be a legislative vehicle to clarify presidential authority to act in anticipation of a severe solar geomagnetic storm?<sup>11</sup> The so-called SHIELD Act, a variant of legislation introduced in prior sessions of the U.S. Congress, would expand the authority of the Federal Energy Regulatory Commission (FERC) to set reliability standards and to provide for cost-recovery for grid-

---

<sup>9</sup> See 28 U.S.C. §2680(a).

<sup>10</sup> Without the design and exercise of reliable emergency communication systems capable of operating through a severe solar geomagnetic storm, the President might be incapable of reliably ordering and authenticating orders to de-energize or re-energize as appropriate electric grid facilities essential to critical national or critical defense infrastructure. President Obama's Executive Order 13618 of July 6, 2012, "Assignment of National Security and Emergency Preparedness Communications Functions," 22 *Federal Register* 40779, does provide in Sec. 2.2: "The Director of the Office of Science and Technology Policy (OSTP) shall: (a) issue an annual memorandum ... highlighting national priorities for Executive Committee analyses, studies, research and development regarding [National Security and Emergency Preparedness] communications;" and to "advise the President" on radio spectrum prioritization.

<sup>11</sup> On June 18, 2013, twenty Members of Congress filed H.R. 2417, the "Secure High-voltage Infrastructure for Electricity from Lethal Damage (SHIELD) Act." Text is available from the Government Printing Office at <http://www.gpo.gov/fdsys/pkg/BILLS-113hr2417ih/pdf/BILLS-113hr2417ih.pdf>.

protective equipment. This legislation is designed to accelerate protection against both a severe solar geomagnetic storm and man-made electromagnetic pulse (EMP) hazards.<sup>12</sup>

In its as-filed text, H.R. 2417 (113<sup>th</sup> Congress) would create a new Section 215A of the Federal Power Act. Under proposed emergency authorities, if the President issues to the Commission “a written directive or determination identifying an immediate grid security threat,” FERC, a five member commission -

“may, with or without notice, hearing, or report, issue such orders for emergency measures as are necessary in its judgment to protect the reliability of the bulk power system or of defense critical electric infrastructure against such threat.”<sup>13</sup>

The proposed emergency measures would require the assembly of a quorum of FERC Commissioners. Even if the Commissioners acted without notice or public hearing, as would be allowed by the proposed legislation, the FERC Commissioners could not, within the 10 to 20 minute confirmatory warning time of the ACE satellite (or its successor satellite) reliably order the de-energizing of critical electric grid equipment in time to preclude permanent damage. It would appear that authorization by the President, and not a Commission of five presidential appointees, would be necessary.

If the President and his team of legal advisers seek clarifying authority for reliable federal action under inherently short warning time, they might consider either supplementing the proposed authorities in H.R. 2417, or proposing some other legislative vehicle to provide the President the authority to issue emergency orders, including the power to de-energize or re-energize critical electric grid equipment and/or “defense critical electric infrastructure.”

In conclusion: the President, in coordination with the Nuclear Regulatory Commission, has existing authority to de-energize critical U.S. electric grid equipment producing about 46% to 47% of annual U.S. net electric generation. These are the gas-fired, petroleum-fired, and nuclear-fueled electric generating facilities.

The President also has emergency powers to mandate the de-energizing of coal-fired electric generating plants, but with the risk of claims of uncompensated “takings” of property and possible federal liability for tort claims.

---

<sup>12</sup> The Foundation for Resilient Societies is organized in the State of New Hampshire as a non-profit corporation with the mission of conducting research and public education on high-impact, low-frequency risks to societal resilience. The Foundation does not endorse H.R. 2417 or any other specific legislation. In this specific instance, the Foundation contrasts the limits of proposed Presidential authority under H.R. 2417 with the practical necessity of action within a 10-to-20 minute warning time for solar storms, and points out that public safety may require alternative or complementary Presidential authority.

<sup>13</sup> H.R. 2417 (June 18, 2013) at page 8, lines 15-20.

The President has an opportunity to obtain clarifying Congressional authority for the President to enable an emergency action system that could, under Presidential order, cause the selective de-energizing and possibly the re-energizing of critical electric grid infrastructure before or during a severe solar geomagnetic storm or, if reliable warning were available, in anticipation of a man-made electromagnetic pulse hazard.

## Appendix 4

### Foundation for Resilient Societies

52 Technology Way

Nashua NH 03060

[www.resilientsocieties.org](http://www.resilientsocieties.org)

June 28, 2013

President Barack Obama  
The White House  
1600 Pennsylvania Avenue NW  
Washington, DC 20500

#### **Subject: Government Emergency Actions on Electromagnetic Pulse Threats**

Dear Mr. President:

We are writing to urge protection of the United States against both man-made and naturally-occurring electromagnetic pulse (EMP). The recent actions of Iran and North Korea—including ongoing nuclear weapons development and missile tests—increase the chance that these nations will threaten and perhaps even execute a high altitude nuclear EMP attack against the continental United States. However, if Presidential initiatives were to protect even a modest proportion of the U.S. electric power grid against EMP, nuclear deterrence could be strengthened and benefits to nuclear proliferators diminished.

The Commission to Assess the Threat to the United States from Electromagnetic Pulse Attack was authorized by the U.S. Congress and worked from 2001 to 2008 to conduct the most comprehensive study to date on EMP protection for civilian infrastructure. We ask the current Administration to revisit and implement selected findings of the EMP Commission. A summary of the EMP Commission findings on protection of electric power infrastructure is included as Appendix 1 to this letter. (Dr. William Graham, chairman of the EMP Commission, is both a director of our Foundation and a signatory to this letter.) Other government bodies also recommending EMP protection include the National Academy of Sciences and the National Intelligence Council.

We commend the Administration for supporting bipartisan efforts to protect against naturally-occurring EMP—also called “solar storms” or “geomagnetic disturbance”—and appreciate the recent White House report, “Space Weather Observing Systems: Current Capabilities and Requirements For The Next Decade.” We also appreciate the positive ruling of the Nuclear Regulatory Commission (NRC) on Petition for Rulemaking PRM-50-96, a petition submitted by our Foundation which would require unattended backup power systems at nuclear power plants vulnerable to solar storm EMP. (See [77 Fed. Reg. 74788-74798](http://www.federalregister.gov); Dec 18, 2012 and Appendix 7 of this letter.) As the events at Fukushima amply showed, nuclear power plants without grid power—and without reliable and protected control and backup systems—can pose a catastrophic danger to surrounding populations. Without power to control and cool reactor cores and spent

fuel pools, thousands of square miles surrounding scores of nuclear power plants in this country could be uninhabitable for centuries in the wake of a national-level EMP event. Additional reports of the EMP Commission are available to authorized persons through the Congress and the Department of Defense.

A high altitude nuclear EMP attack from North Korea is an imminent threat to the United States, and an EMP attack from Iran could shortly become an imminent threat. We propose three protective actions against rogue nations with nuclear EMP capability. In the short term, we propose emergency deployment of cost-effective missile defense systems, including Aegis systems that can defend against southern approaches to the continental United States; this proposal is more fully explained in Appendix 2. In the medium term, we propose E1 (fast pulse) protection of electric grid control rooms at regional balancing authorities, as well as E1 and E3 (magnetohydrodynamic pulse) protection of critical Extra High Voltage (EHV) transformers. This protection, while incomplete, would increase the uncertainty of a successful nuclear EMP attack and could have substantial deterrent effect upon rogue state adversaries. In the long-term, we propose that all high-priority critical infrastructures when upgraded or replaced should be subject to nuclear EMP protection standards; for example, all of the Bulk Power System under jurisdiction of FERC should eventually have both E1 and E3 protection.

Engineering practices for EMP protection are well developed and have been successfully implemented by the Department of Defense (DoD) for its strategic systems. The American public deserves protection for critical civilian infrastructure as well. It is particularly important for DoD to make its expertise available to the Department of Homeland Security, the Department of Energy, NRC, FERC, and the electric power industry. A summary of DoD expertise that could be used to provide EMP protection for the U.S. electric power grid is provided in Appendix 3.

While FERC has a standard for solar storm EMP protection in development, the timeline for installation of protective hardware will be in year 2015 at the earliest. In the meantime, and during the peak and active backside of the 11-year solar cycle, the United States will be unprotected, absent a government emergency plan to de-energize the electric grid upon warning of a severe solar storm. De-energizing transformers with long replacement times could reduce grid recovery time and save millions of lives.

Our legal analysis indicates that the President has existing authority to de-energize substantial portions of the three U.S. regional grid interconnections, including all nuclear, gas-fired, and oil-fired generation facilities. We understand from the NOAA Space Weather Prediction Center that a final 10 to 20-minute warning from the ACE satellite, as well as preliminary two-day warnings from space satellites closer to the sun, could be part of a feasible plan to de-energize vulnerable equipment within the electric grid. While the final warning time would be short, de-energizing the most vulnerable portions of the U.S. electric grid could still be accomplished if an emergency plan had previously been developed and all necessary processes and procedures were in place. Significantly, Presidential authority to de-energize critical generation facilities is non-delegable, except for nuclear power plants where the NRC has direct authority. More background on an emergency plan to de-energize generation facilities is explained in Appendix 4 of this letter; a review of Presidential legal authority is presented in Appendix 5.


In the fall of 2012 our Foundation conducted a pilot qualitative survey of national security and foreign policy experts regarding awareness of EMP threats. To our surprise, we found that EMP threats are poorly understood and often discounted among these experts, despite nuclear EMP protection being required for U.S. strategic defense systems and continuity of government for more than 40 years. Some in Washington view EMP as a problem without a ready solution and therefore politically infeasible to address. In actuality, Idaho National Laboratory has already tested a neutral blocking device to protect transformers against both nuclear E3 and severe solar storms. This blocking device is commercially available for a cost of \$250,000 per substation. Furthermore, at least one electric utility (Centerpoint Energy in Houston, Texas) has installed on its own initiative a nuclear E1 hardened control room at a cost of \$8.75 million dollars. Nations such as Israel are already implementing cost-effective EMP protection for their electric grids.

Focused EMP protection of the most critical infrastructure would be both practical and cost-effective. But lack of timely EMP protection could result in the death of over one hundred million Americans and threaten the existence of the United States as a functioning country.

There is increasing public awareness and concern over EMP threats. This legitimate public concern, if not addressed, could have a destabilizing effect on our society. Already there is a “prepper” movement, where individual citizens store food and water and sometimes take more extreme measures. But no amount of personal preparation can supplant the constitutional duty of the federal government to provide for a common defense. We urge the Administration to take concrete steps for EMP protection before the next major solar storm and before the Islamic Republic of Iran conducts a successful nuclear test. Actions for EMP protection must be made public—secret plans will not reassure the populace, nor will secret EMP defenses deter rogue nations.

Given the importance and immediacy of EMP threats to the United States and its population, we ask for the courtesy of a reply from the Administration. Thank you for consideration of our concerns.

Sincerely,



Dr. William R. Graham, Chair of Congressional EMP Commission and former Assistant to the President for Science and Technology



Ambassador Henry F. Cooper, former Director of the Strategic Defense Initiative Organization



Dr. George H. Baker, Professor Emeritus, James Madison University



William R. Harris, International Lawyer & Secretary, Foundation for Resilient Societies



Stephen L. Mott, Nuclear Engineer; 30 years' experience in the nuclear power industry



Thomas S. Popik, Chairman, Foundation for Resilient Societies

Attachments:

**Appendix 1:** Extracts from Executive Report of Commission to Assess the Threat to the United States from Electromagnetic Pulse Attack

**Appendix 2:** An Immediate Plan to Defend U.S. against Nuclear EMP Attack

**Appendix 3:** EMP/GMD Protection of the U.S. Electric Power Grid

**Appendix 4:** Presidential Plan to Protect from Long-Term Electric Grid Outage Due to GMD

**Appendix 5:** Legal Authority for the President of the United States to Order Interruption of U.S. Electric Generation and Related Electric Grid Protections during a Severe Solar Geomagnetic Storm

**Appendix 6:** Recognizing Electromagnetic Pulse Attack

**Appendix 7:** Vulnerability of Nuclear Power Plants to Electromagnetic Pulse

cc:

**The White House**

Sylvia Mathews Burwell, Director, Office of Management and Budget

John P. Holdren, Director, Office of Science and Technology Policy

Lisa O. Monaco, Assistant to the President for Homeland Security and Counterterrorism

Susan E. Rice, Assistant to the President for National Security Affairs

**Departments**

Charles T. Hagel, Secretary of Defense

John F. Kerry, Secretary of State

Ernest J. Moniz, Secretary of Energy

Janet Napolitano, Secretary of Homeland Security

**Agencies**

James R. Clapper, Director of National Intelligence

Allison M. Macfarlane, Chairman, Nuclear Regulatory Commission

Kathryn Sullivan, Acting NOAA Administrator

Jon Wellinghoff, Chairman, Federal Energy Regulatory Commission

## **Letter to President Obama: Appendix 1**

Extracts from Executive Report of Commission to Assess the Threat to the United States from Electromagnetic Pulse Attack

Full report available at [http://www.empcommission.org/docs/empc\\_exec\\_rpt.pdf](http://www.empcommission.org/docs/empc_exec_rpt.pdf).

### **ABSTRACT**

Several potential adversaries have or can acquire the capability to attack the United States with a high-altitude nuclear weapon-generated electromagnetic pulse (EMP). A determined adversary can achieve an EMP attack capability without having a high level of sophistication.

EMP is one of a small number of threats that can hold our society at risk of catastrophic consequences. EMP will cover the wide geographic region within line of sight to the nuclear weapon. It has the capability to produce significant damage to critical infrastructures and thus to the very fabric of US society, as well as to the ability of the US and Western nations to project influence and military power.

The common element that can produce such an impact from EMP is primarily electronics, so pervasive in all aspects of our society and military, coupled through critical infrastructures. Our vulnerability is increasing daily as our use of and dependence on electronics continues to grow. The impact of EMP is asymmetric in relation to potential protagonists who are not as dependent on modern electronics.


The current vulnerability of our critical infrastructures can both invite and reward attack if not corrected. Correction is feasible and well within the Nation's means and resources to accomplish.

# ELECTRIC POWER INFRASTRUCTURE

## *Nature of the Problem*

Electric power is integral to the functioning of electronic components. For highly reliable systems such as commercial and military telecommunications, electric power usually comes from batteries (in the short term), local emergency power supplies (generally over time-intervals of less than 72 hours), and electricity delivered through the local electrical utility (“power” lines in the home, office and factory). Local emergency power supplies are limited by supplies of stored fuel. Increasingly, locally-stored fuel in buildings and cities is being reduced for fire safety and environmental pollution reasons, so that the emergency generation availability without refueling is limited.

Geomagnetic storms, a natural phenomenon driven by the solar wind, may, by a different physical mechanism, produce ground-induced currents (GIC) that can affect the electrical system in a manner similar to the E3 component of EMP. Disruptions caused by geomagnetic storms, such as the collapse of Quebec Hydro grid during the geomagnetic storm of 1989, have occurred many times in the past (Figure 5).



Source: Metatech Corporation, Applied Power Solutions

**Figure 5. Extent of 1989 Geomagnetic Storm**

Depending on the explosive yield of the nuclear weapon used, EMP-induced GIC may be several times larger than that produced by the average geomagnetic storm, and may even be comparable to those expected to arise in the largest geomagnetic storm ever observed. It may also occur over an area not normally affected by historic geomagnetic storms.

The North American economy and the functioning of the society as a whole are critically dependent on the availability of electricity, as needed, where and when needed. The electric power system in the US and interconnected areas of Canada and Mexico is outstanding in terms of its ability to meet load demands with high quality and reliable electricity at reasonable cost. However, over the last decade or two, there has been relatively little large-capacity electric transmission constructed and the generation additions that have been made, while barely adequate, have been increasingly located considerable distances from load for environmental, political, and economic reasons. As a result, the existing National electrical system not infrequently operates at or very near local limits on its physical capacity to move power from generation to load. Therefore, the slightest insult or upset to the system can cause functional collapse affecting significant numbers of people, businesses, and manufacturing. It is not surprising that a single EMP attack may well encompass and degrade at least 70% of the Nation's electrical service, all in one instant.

The impact of such EMP is different and far more catastrophic than that affected by historic blackouts, in three primary respects:

1. The EMP impact is virtually instantaneous and occurs simultaneously over a much larger geographic area. Generally, there are no precursors nor warning, and no opportunity for human-initiated protective action. The early-time EMP component is the "electromagnetic shock" that disrupts or damages electronics-based control systems and sensors, communication systems, protective systems, and control computers; all of which are used to control and bring electricity from generation sites to customer loads in the quantity and quality needed. The E1 pulse also causes some insulator flashovers in the lower-voltage electricity distribution systems (those found in suburban neighborhoods, in rural areas and inside cities), resulting in immediate broad-scale loss-of-load. Functional collapse of the power system is almost definite over the entire affected region, and may cascade into adjacent geographic areas.
2. The middle-time EMP component is similar to lightning in its time-dependence, but is far more widespread in its character although of lower amplitude—essentially a great many lightning-type insults over a large geographic area which might obviate protection. The late-time EMP component couples very efficiently to long electrical transmission lines and forces large direct electrical currents to flow in them, although they're designed to carry only alternating currents. The energy levels thereby concentrated at the ends of these long lines can become large enough to damage major electrical power system components. The most significant risk is synergistic, because the

middle and late time pulses follow after the early time, which can impair or destroy protective and control features of the power grid. Then the energies associated with the middle and late time EMP thus may pass into major system components and damage them. It may also pass electrical surges or fault currents into the loads connected to the system, creating damage in national assets that are not normally considered part of the infrastructure *per se*. Net result is recovery times of months to years, instead of days to weeks.

3. Proper functioning of the electrical power system requires communication systems, financial systems, transportation systems and, for much of the generation, continuous or nearly continuous supply of various fuels. However, the fuel-supply, communications, transportation, and financial infrastructures would be simultaneously disabled or degraded in an EMP attack and are dependent upon electricity for proper functioning. For electrical system recovery and restoration of service, the availability of these other infrastructures is essential. The longer the outage, the more problematic, and uncertainty-fraught the recovery will be.

The recent cascading outage of August 14, 2003, is an example of a single failure compounded by system weaknesses and human mistakes. It also provided an example of the effectiveness of protective equipment. However, with EMP there are multiple insults coupled with the disabling of protective devices simultaneously over an extremely broad region—damage to the system is likely and recovery slow.

#### *Recommended Mitigation and Responsibility*

The electrical system is designed to break into “islands” of roughly matching generation and load when a portion of the system receives a severe electrical insult. This serves both to protect electricity supply in the non-impacted regions and to allow for the stable island-systems to be used to “restart” the island(s) that have lost functionality. With EMP, the magnitude, speed, and multi-faceted nature of the insult, its broad geographic reach, along with the number of simultaneous insults, and the adverse synergies all are likely to result in a situation where the islanding scheme will fail to perform as effectively as intended, if at all. Since the impacted geographic area is large, restoring the system from the still-functioning perimeter regions would take a great deal of time, possibly weeks to months at best. Indeed, the only practical way to restart much of the impacted electrical system may be with generation that can be started without an external power source. This is called “black start” generation and primarily includes hydroelectric (including pumped storage), geothermal, and independent diesel generators of modest capacity.

The recommended actions will substantially improve service and recovery during ‘normal’ large-scale blackouts, as well as critically enabling recovery under EMP circumstances.

### *Protection*

It is impractical to protect the entire electrical power system from damage by an EMP attack. There are too many components of too many different types, manufacturers, designs and vulnerabilities within too many jurisdictional entities, and the cost to retrofit is too great.

Widespread functional collapse of the electrical power system in the area affected by EMP is likely in the face of a geographically broad EMP attack, with even a relatively few unprotected

***Widespread functional collapse of the electric power system in the area affected by EMP is likely.***

components in place. However, it is practical to reduce to low levels the probability of widespread damage to major power system components that require long times to replace. This will enable significantly improved recovery times, since it avoids the loss of long lead-time and critical components. It is important to protect the ability of the system to fragment gracefully into islands, to the extent practical in the particular EMP circumstance. This approach is cost-efficient, and can leverage efforts to improve reliability of bulk electricity supply and enhance its security against the broader range of threats.

### *Restoration*

The key to minimizing adverse effects from loss of electrical power is the speed of restoration. Restoration involves matching generation capacity to a load of equivalent size over a transmission network that is initially isolated from the broader system. The larger system is then functionally rebuilt by bringing that mini system or ‘island’ to the standard operating frequency and thereupon by adding on more blocks of generation and load to this core- in amounts that allow the growing subsystem to absorb. This is a demanding and time-consuming process in the best of circumstances. In the singular circumstance of an EMP attack with multiple damaged components, related infrastructure failures, and particularly severe challenges in communications and transportation, the time required to restore electrical power is expected to be considerably longer than we have experienced in recent history.

However, by protecting key system components needed for restoration, by structuring the network to fail gracefully, and by creating a comprehensive prioritized recovery plan for the most critical power needs, the risk of an EMP attack having a catastrophic effect on the Nation can be greatly reduced. DHS must ensure that the mitigation plan is jointly developed by the Federal government and the electric power industry, implemented fully, instilled into systems operations and tested and practiced regularly to maintain a capability to respond effectively in emergencies. The North American Reliability Council and the Electric Power Research Institute are aptly positioned to provide much of what’s needed to support DHS in carrying out its responsibilities. The US Energy Association is well-suited to coordinating activities between and among the various energy sectors that together affect the electric power system and its vitality.

## *Essential Component Protection*

1. Assure protection of high-value long-lead-time transmission assets.
2. Assure protection of high-value generation assets. System-level protection assurance is more complex due to the need for multiple systems to function in proper sequence.
3. Assure Key Generation Capability. Not all plants can or should be protected. However, regional evaluation of key generating resources necessary for recovery should be selected and protected.
  - a. Coal-fired generation plants make up nearly half the Nation's generation and are generally the most robust overall to EMP, with many electromechanical controls still in operation. Such coal plants also normally have at least a few days to a month of on-site fuel storage.
  - b. Natural gas-fired combustion turbines and associated steam secondary systems represent the newest and a significant contributor to meeting loads. These have modern electronics-based control and thus are more vulnerable. Natural gas is not stored on-site and likely will be interrupted in an EMP attack. However, provision can be made to have gas-fired plants also operate on fuel oil; many do already.
  - c. Nuclear plants produce roughly 20% of the Nation's generation and have many redundant fail-safe systems that tend to remove them from service whenever any system upset is sensed. Their safe shut down should be assured, but they will be unavailable until near the end of restoration.
  - d. Hydroelectric power is generally quite robust to EMP, and constitutes a substantial fraction of total national generation capacity, albeit unevenly distributed geographically.
  - e. In general, the various distributed and renewable fueled generators are not significant enough at this time to warrant special protection.
  - f. "Black start" generation of all types is critical will need to be protected from EMP upset or damage.
4. Assure functional integrity of critical communications channels. The most critical communications channels in the power grid are the ones that enable recovery from collapse, such as ones that enable manual operation and coordination-supporting contacts between distant system operators and those that support system diagnostics. Generation, switching, and load dispatch communications support is next in importance.
5. Assure availability of emergency power at critical facilities needed for restoration. Transmission substations need uninterruptible power to support rapid restoration of grid connectivity and operability, and thereby to more quickly restore service. Most have short-life battery backup systems, but relatively few have longer-duration emergency generators; much more emphasis on the latter is needed.

6. Assure protection of fuel production and its delivery for generation. Fuel supply adequate to maintain critical electrical service and to restore expanded service is critical. See Fuel/Energy Infrastructure, page 34) for details.
7. Expand and assure intelligent islanding capability. The ability of the larger electrical power system to break into relatively small subsystem 'islands' is important to mitigate overall EMP impacts and provide faster restoration.
8. Develop and deploy system test standards and equipment. Device-level robustness standards and test equipment exist, but protection at the system level is the overarching goal. System level robustness improvements such as isolators, line protection, and grounding improvements will be the most practical and least expensive in most cases relative to replacement with more robust individual component devices. Periodic testing of system response is necessary.

### *System Restoration*

1. Develop and enable a restoration plan. This plan must prioritize the rapid restoration of power to government-identified critical service. Sufficient "black start" generation capacity must be provided where it's needed in the associated subsystem islands, along with transmission system paths that can be isolated and connected to matching loads. The plan must address outages with wide geographic coverage, multiple major component failures, poor communication capabilities, and widespread failure of islanding schemes within the EMP-affected area. Government and industry responsibilities must be unequivocally and completely assigned. All necessary legal and financial arrangements, e.g., for indemnification, must be put into place to allow industry to implement specified government priorities with respect to service restoration, as well as to deal with potential environmental and technical hazards in order to assure rapid recovery.
2. Simulate, train, exercise, and test the plan. Simulators must be developed for use in training and developing procedures similar to those in the airline industry; a handful should suffice for the entire country. Along with simulation and field exercises, Red Team discipline should be employed to surface weaknesses and prioritize their rectification.
3. Assure sufficient numbers of adequately trained recovery personnel.
4. Assure availability of replacement equipment. R&D is under way—and should be vigorously pursued—into the production of emergency "universal" replacements. The emergency nature of such devices would trade efficiency and service-life for modularity, transportability, and affordability.
5. Implement redundant backup diagnostics and communication. Assure that system operators can reliably identify and locate damaged components.

## **Letter to President Obama: Appendix 2**

### **An Immediate Plan to Defend the U.S. against Nuclear EMP Attack**

*Considered below are: the nature of the electromagnetic pulse (EMP) threat posed by several ballistic missile attack scenarios; near term ways to defend against such scenarios; and a possible diplomatic adjunct to assure the effectiveness of some of these defenses.*

#### **Nature of the New Nuclear EMP Threat**

During the Cold War, U.S. strategic planners assumed that any attack by the Soviet Union on the United States would begin with high-altitude nuclear detonations to generate EMP and disrupt or destroy strategic mission critical communications and other electronic systems. Former Soviet planners have confirmed this attack scenario since the fall of the Berlin Wall and subsequent dissolution of the Soviet Union. In accordance with U.S. defense doctrine, Department of Defense policy required EMP-hardening of our strategic forces and supporting command, control and communication systems to assure that these systems could survive a massive Soviet attack and permit the National Command Authority to authorize a devastating retaliatory strike.

While our current strategic force planning still includes “nuclear deterrence” plans, the range of international adversaries and threat scenarios has expanded since the end of the Cold War. In addition to states with large nuclear arsenals such as Russia and China, the United States is now threatened by rogue states such as North Korea and Iran, as well as terrorist organizations that may obtain nuclear weapons on the black market or from proliferators. U.S. strategic force planning needs to adjust to these new nuclear threat scenarios.

During the Cold War, EMP was a highly classified topic. A reduced threat environment at end of the Cold War brought extensive disclosure on Soviet atmospheric tests of EMP phenomena, as well as additional disclosure of United States EMP tests. Rogue nations, nuclear proliferators, and terrorist organizations are now well aware of the devastating nature of the EMP attack vector.

Increasing societal reliance on electric power and sophisticated electronic devices has also increased vulnerability to EMP attack. Because of the fragility of the electric power grid and ubiquitous use of integrated circuits, an EMP attack by a single nuclear device could pose an existential threat to the United States and its population. But we as a nation have not yet developed the conceptual framework or practical means to cope with today’s EMP threat, even as rogue nations such as Iran threaten EMP attack in their rhetoric and military literature.

Some national security experts now recognize the EMP threat and consider it a subset of threats that target highly industrialized “information societies.” For example, on May 23, 2013, former CIA Director R. James Woolsey testified to the House Energy and Commerce Committee that our cyber and information warfare doctrines are dangerously blind to an all-out information warfare campaign designed to cripple U.S. critical infrastructures. Because EMP would destroy both the electric power grid and integrated circuits essential to computers, EMP could be a key component of an information warfare attack.

Mr. Woolsey noted that his assessment reflected the 2001-2008 work of the Congressional EMP Commission, the subsequent Congressional Strategic Posture Commission, and several other major U.S. Government studies—collectively representing a non-partisan scientific and strategic consensus that such an attack upon the United States is an existential threat. The foundation for identifying the existential nature of the information warfare and EMP threats was laid by the unanimous conclusions

(based on all-source intelligence) of the 1998 Commission to Assess the Ballistic Missile Threat to the United States. In the intervening 15 years since this Commission, subsequent Commissions have met, but little has been done to adjust U.S. strategic planning.

Mr. Woolsey, who was a member of the above mentioned Commissions, testified that Russia, China, North Korea, and Iran all include in their strategic doctrine and plans a wide spectrum of information warfare threats, including cyber-attack, sabotage and kinetic attacks on key system nodes, and wide-area EMP attack. The EMP component of an information warfare attack could be executed by a long-range ballistic missile launched from the homeland of these states. However, a more simple—and perhaps less defensible—EMP attack could be executed by a short-range ballistic missile launched from a ship near the U.S. coast. Even unsophisticated and under-resourced terrorists could threaten EMP attack by mating a small nuclear device to a SCUD missile—or other missile of simple design—and mounting the missile and payload to a small freighter.

Perhaps the most troubling of these potential threats comes from North Korea and Iran, both of which have benefited from nuclear and ballistic missile technology obtained from Russia and China. Furthermore, Russia and China have an excellent understanding of EMP effects, and their scientists, whether officially authorized or not, have proliferated this information to North Korea and Iran.

Both North Korea and Iran have launched ballistic missiles in large numbers as part of military exercises; both have demonstrated intercontinental ballistic missile (ICBM) range capability; and both have placed satellites in orbit. Notably, North Korea and Iran have launched satellites over the South Polar region to approach the United States from the south in their maiden orbit at a few hundred miles altitude—just right for casting EMP effects over the entire continental United States. Unfortunately, our primary missile defenses are arrayed against ICBMs that approach the United States from trajectories near to the North Pole, a fact that is surely known to North Korean and Iranian war planners.

North Korea has conducted three underground nuclear tests, including the most recent test in February 2013. Open source reports indicate that Iranian scientists have been present at North Korean nuclear tests—and it is not implausible to suggest that when North Korea is satisfied with a given nuclear design, Iran may be also.

Some reports have characterized North Korean tests as "failures" because of their low explosive yield. However, North Korea may be testing light-weight, low-yield advanced nuclear weapon designs obtained from Russia or China. These specialized devices may be designed to produce a low explosive yield, but a significantly higher output of gamma rays. In operational use, the gamma rays produced by such weapon designs would interact with the earth's magnetic field to produce enhanced EMP effects. Low-yield entry-level weapons—even those without EMP enhancements—if detonated at an altitude of 60-70 kilometers will produce EMP fields sufficient to cause permanent damage to integrated circuits.

Because of technical interchanges between North Korea and Iran, there should be great concern that Iran will be following North Korea's lead in short order—perhaps even concurrently—to mate EMP-enhanced weapons to ballistic missiles or to include light-weight EMP weapons as satellite payloads.

Iran clearly understands how to leverage EMP effects created by nuclear weapons in its strategic and tactical planning. Mr. Woolsey testified that Iranian doctrinal writings include assertions such as:

- “Nuclear weapons . . . can be used to determine the outcome of a war, without inflicting serious human damage [by neutralizing] strategic and information networks;”

- “Terrorist information warfare [includes] the technology of directed energy (DEW) or electromagnetic pulse (EMP);” and
- “. . . [W]hen you disable a country’s military’s high command through disruption of communications you will, in effect, disrupt all the affairs of that country. . . . If the world’s industrial countries fail to devise effective ways to defend themselves against dangerous electronic assaults, then they will disintegrate within a few years.”

Finally, Iran first launched a ballistic missile from a vessel in the Caspian Sea over a decade ago and, as Mr. Woolsey testified, has several times demonstrated the capability to detonate a warhead at the high-altitudes necessary for an EMP attack on the entire United States. Thus, these tests are signatures of Iranian planning for an EMP attack that could be launched from a vessel off the U.S. coast.

In summary, there are multiple indicators that rogue nations and terrorist organizations are aware of the destructive potential of EMP attack, have included EMP attack in their war plans, and could soon have an ability to execute such an attack. Time is short for the United States to develop EMP defenses.

### **Gaps in Our Defenses against EMP Attacks**

Our strategic defenses should be designed to deter and defeat the war-fighting doctrines of nations with substantial nuclear arsenals, rogue states with just a few nuclear weapons, and terrorist organizations that obtain nuclear weapons on the black market or from proliferators. But, regrettably, our current defenses are focused on intercontinental missile attack via northern trajectories, and therefore leave the United States vulnerable to an EMP attack in at least three major ways:

- Nuclear-armed ballistic missiles launched from ships off our coasts and detonated a hundred miles or so over the United States;
- Nuclear-armed ballistic missiles launched from an aircraft and detonated over the United States; and
- Detonation of a nuclear weapon carried on a low earth orbit satellite as it passes over the United States.

None of these attack modes offer significant technological challenges to nation states with a modicum of nuclear weapon and ballistic missile technology. Indeed, in the 1960s, the United States launched Minutemen intercontinental ballistic missiles (ICBMs) both from a ship and a cargo aircraft. The Soviet Union deployed a Fractional Orbital Bombardment System (FOBS) designed to carry a nuclear weapon over the South Pole and to be de-orbited to attack anyplace on earth. Their dedicated FOBS site, operational between November 1968 and January 1983, was dismantled following June 1982 diplomatic commitments relating to the unratified SALT II Treaty.<sup>1</sup> There is now no international agreement that prohibits a ready-to-launch FOBS to detonate a nuclear weapon in outer space.<sup>2</sup>

---

<sup>1</sup> See "The Soviet Fractional Orbital Bombardment System Program," Technical Report APA-TR-2010-0101 by Miroslav Gyűrösi, January 2010 (updated April 2012), available at <http://www.ausairpower.net/APA-Sov-FOBS-Program.html>, last accessed June 23, 2013.

<sup>2</sup> However, the *employment* of a space-based nuclear EMP weapon, whether launched by a FOBS system or otherwise, would constitute a “material breach” of the U.N. Convention on Environmental Modification, the ENMOD Treaty of 1977. This Convention entered into force on October 5, 1978; for the U.S. on January 17, 1980. It prohibits environmental modifications with “widespread, long-lasting or severe effects” as the means of “destruction, damage, or injury to any other State Party.” North Korea ratified the ENMOD Convention on

The Outer Space Treaty of 1967 prohibits placing nuclear weapons in space orbit. This agreement can be circumvented simply by preparing a ready-to-launch vehicle with a nuclear weapon and placing the launch vehicle in reserve. Upon launch during international crisis, the satellite and nuclear weapon payload could be placed in a longitudinally progressive polar orbit that would eventually be above any point on earth. When above the location of choice, and upon command, the nuclear weapon could then be detonated to produce an EMP attack. Not only Russia and China, but also North Korea and Iran have demonstrated an inherent capability to execute such an attack.

While satellite tracking systems could pinpoint the responsible nation for a satellite-based EMP attack, there is no similar assurance for an attack from a ship or aircraft. And without the National Command Authority knowing the origin of an EMP attack, the doctrine of deterrence based on massive nuclear retaliation fails. Retaliatory doctrines also fail in the case of terrorists prepared to commit suicide to kill several hundred million Americans. While terrorists might find it difficult to carry out an aircraft or satellite-based EMP attack, short range ballistic missiles and their mobile launchers can be easily purchased and carried covertly on any of the numerous vessels daily traversing near U.S. national waters. Thus, deploying defenses to counter the ship-based EMP attack scenario deserves top priority in rectifying the nation's current vulnerability to an EMP attack. Fortunately, there are operational capabilities that can be quickly adapted to provide such an EMP defense.

### **Near-Term Defenses against EMP Threats from Ships Off our Coasts**

The nearest term defense against ship-based EMP attack can be provided by the U.S. Navy's Aegis Ballistic Missile Defense (BMD) system. In its impressive test record—26 successful intercepts out of 32 attempts, all executed by operational crews—the Aegis BMD system has already demonstrated it can shoot down short, medium and intermediate range ballistic missiles, in both their ascent (post-burnout) and midcourse phases of flight. Today, there are 27 Aegis BMD Cruisers and Destroyers at sea around the world—currently funded plans will grow this number to 35 by 2017 and more of the approximately 80 Aegis ships could be given BMD capability for less than \$50 million per ship. The marginal cost of the current SM-3 interceptor is less than \$10 million per interceptor.

For Aegis BMD ships to protect the United States from an EMP attack, there are two prerequisites. First, Aegis crews must be operationally trained to intercept missiles in their ascent and midcourse phases of flight—as they are. Second, Aegis ships must be in the vicinity of the ship from which a potential attack is launched. Normally, a few Aegis BMD ships are near our east and west coasts or in a coastal port—where they can maintain a BMD operational status if desired and so ordered. Furthermore, if these coastal ships were to be periodically tested against short and medium range ballistic missiles near our east and west coasts, such tests could contribute to deterring a terrorist EMP attack.

However, defending against an EMP attack from the Gulf of Mexico is not so easily and quickly addressed, because our Aegis BMD ships do not normally traverse the Gulf—and these ships are needed overseas by our global combatant commanders. Thus, except for an urgent requirement, perhaps on the basis of confirmed strategic warning, the United States will remain vulnerable to an EMP attack from the Gulf (or from the south, e.g., Venezuela) until a dedicated defense against this contingency is provided.

A near-term dedicated defense against short and medium range missiles launched from the south would be to deploy Aegis Ashore sites on several military bases proximate to the Gulf of Mexico. Development of the Aegis Ashore concept is approved and funds are being appropriated for deployment in Romania

---

November 8, 1984. Iran became a treaty signatory on May 18, 1977, but did not ratify. Iran has a continuing duty not to act so as to defeat the "object and purpose" of the Convention.

(2015) and Poland (2018). No additional development costs would be required to deploy the same system concept at key locations proximate to the Gulf of Mexico. Associated site selection and environmental impact studies would be required, of course. Given the approved plans for an initial Aegis Ashore site in Romania by 2015, it should be possible to deploy the first Gulf of Mexico site by that same date, or possibly sooner.

The Defense Authorization Act for FY2014, reported favorably by the Senate Armed Services Committee (SASC) in June 2013<sup>3</sup> could provide an expedited process to evaluate missile defense options against EMP threats to the homeland. If enacted, this legislation would direct the Secretary of Defense to submit to Congress within 180 days after enactment, a report on several potential future options for enhancing United States homeland ballistic missile defense. Among them, the SASC proposal explicitly calls for consideration of missile defense options to “defend the United States homeland against ballistic missiles that could be launched from vessels on the seas around the United States, including the Gulf of Mexico, or other ballistic missile threats that could approach the United States from the south, should such a threat arise in the future.” An example of this latter important future threat is discussed below.

### **Near-Term Defenses Against EMP Attacks from Over the South Pole**

Concepts for Aegis-based ballistic missile defense (i.e., both the currently deployed ships and future Aegis Ashore sites) should be integrated into the global missile defense architecture. Furthermore, the Aegis SPY-1 radar provides important tracking and warning information to this global system—and provides an important complement to the nation’s BMD warning, attack assessment and tracking capability which historically has focused on detecting and countering ballistic missile attack over via trajectories close to the North Pole.

In addition to the U.S. space sensors and other limited surface sensor capabilities, all the Aegis ships deployed worldwide, whether BMD capable or not, can help provide warning and tracking information to the BMD global command and control system. And this global system can provide critical information on attacks that come from either north or south.

In particular, a global tracking capability would help counter ballistic missile attacks that might come over the South Pole from North Korea or Iran—both nations have already launched satellites in such South Polar orbits that pass over the U.S. With such warning and track information on attacks over the South Pole, our ground-based interceptors, particularly those based in California, may be capable of intercepting an attacking satellite before it orbits over the United States.

If such a potential satellite-based attack is detected in time and tracked by our forward-based Aegis ships and other integrated sensors, other “downstream” Aegis BMD ships would also have a chance to shoot down the satellite before it overflies U.S. territory — even earlier than the longer range ground-based interceptors in California. (In 2008, the currently deployed Aegis BMD system shot down a dying satellite over the Pacific Ocean to protect cities from the toxic fuel it carried.)

In summary, a “South Pole” EMP attack via an orbiting satellite is within the near-term capabilities of rogue nations such as North Korea and Iran. Deploying a single-layer defense using ship-based or land-based AEGIS systems should be immediately feasible and could provide substantial deterrent effect.

---

<sup>3</sup> See S. Rpt. 113-044, accompanying [S.1197, the Defense Authorization Act for FY2014](#) as reported to the Senate on June 20, 2013. Text of Sec. 231 is available at <http://www.gpo.gov/fdsys/pkg/BILLS-113s1197pcs/pdf/BILLS-113s1197pcs.pdf>.

Deploying a multi-layered defense against such “Attacks from the South” should be feasible within three years and could provide both deterrent effect and high-certainty defense.

### **An Associated Arms Control Challenge for Prevention of Satellite-Based EMP Attack**

A key problem in defending against a FOBS is determining within a very few minutes after a satellite is launched to the south from North Korea or Iran (indeed from anywhere) that it carries a threatening nuclear weapon. Therein is a challenge for arms control and/or other diplomatic constraints.

Effective verification of arms control agreements banning potential satellite-based EMP attack would be very difficult but not impossible. More effective would be a multilateral agreement to inspect by appropriate means all space launch payloads to be launched to the south once on the launch pad but shortly before launch, with the agreed understanding that all noncomplying launched payloads will be shot down. As previously explained, the Outer Space Treaty of 1967 already prohibits placing weapons of mass destruction in space orbit, but cooperative verification measures are lacking.<sup>4</sup>

Developing acceptably-intrusive and mission effective sensors to assure compliance should be a high priority program to accompany negotiations to achieve such an international agreement. Given the practical difficulty of effectively shielding radiation emitted from a low-weight nuclear device to be placed on a satellite, cooperative verification of payload signatures may be useful. Nonetheless, it will be a significant challenge to assure detection of a nuclear weapon while at the same time not betraying compromising other national security secrets. Any verification procedure must apply to all parties and in particular must not compromise U.S. national security interests.

### **Concluding Comments**

EMP attack is an imminent threat and potential adversaries—including North Korea, Iran, and terrorists—well understand how to execute this kind of attack. Especially Iran, once it achieves a nuclear weapon that can be mated to essentially any of its many ballistic missile systems, poses an imminent existential threat to the United States. Iran might deliver such an attack directly (e.g., by launching a nuclear weapon on a satellite over the South Pole and detonating it in its first orbit over the United States) or it might engage surrogate terrorists to launch a high-altitude EMP attack from a vessel near our coasts.

Our current homeland missile defense systems are deployed primarily to defend against ICBMs that approach the United States from the north—over the North Pole. Urgently needed are defenses against EMP attacks that might be launched from vessels off our coasts—particularly off the coast of the Gulf of Mexico. Near term and relatively inexpensive defenses are feasible using existing Aegis ballistic missile

---

<sup>4</sup> Article IV of the Outer Space Treaty provides that “State Parties... undertake not to place in orbit around the Earth any objects carrying nuclear weapons or any other kinds of weapons of mass destruction.” Both Iran and North Korea are signatory states, but without treaty ratification are not “state parties.” With at least 102 State Parties, this treaty may constitute a peremptory norm of international law binding not only “state parties” but also “non-state parties.”

Complicating verification requirements for the Outer Space Treaty is the need to distinguish pre-launch nuclear power sources for space missions from pre-launch nuclear weapons payloads. United National General Assembly Resolution 47/68 of December 24, 1992 sets forth “Principles Relevant to the Use of Nuclear Power Sources in Outer Space.” Highly enriched uranium 235 is a mandatory fuel source. When nuclear power sources are to be used for space missions, prior public reporting and prior notification to the United Nations are established U.N. procedures. See “Safety Framework for Nuclear Power Source Applications in Outer Space.” UN A/AC.105/934. /

defense systems, both ship-based and land-based. We also need defenses and a companion diplomatic strategy to counter the possible threat posed by a nuclear weapon carried by a satellite in a south polar orbit, which might be detonated in its maiden orbit before currently deployed defenses can counter it. Confident warning and attack assessment information is needed to defend against this EMP attack scenario—which may be aided by an appropriate diplomatic strategy employing pre-launch payload inspections and related confidence building measures.

## **Letter to President Obama: Appendix 3**

### **EMP/GMD Protection of the U.S. Electric Power Grid**

The Commission to Assess the Threat to the United States from Electromagnetic Pulse Attack has provided a compelling case for protecting civilian infrastructure against the effects of nuclear EMP and geomagnetic disturbances (GMDs) caused by severe solar storms. According to the findings of the EMP Commission, the electric power grid is the infrastructure that is most vulnerable to nuclear EMP and solar GMD. Our most vulnerable infrastructure is arguably also the most critical since it is necessary for the operation of all other infrastructure sectors. In addition, experience from Hurricanes Sandy and Katrina clearly demonstrates that the electric power grid is essential to prompt disaster recovery.

The nuclear EMP and solar GMD phenomena are more challenging than conventional weather-related catastrophes in that the affected geography can be continental in scale. These wide-area electromagnetic effects represent a class of high-consequence disasters that is unique in coverage and ubiquitous system debilitation. Such disasters deserve particular attention with regard to preparedness and recovery since assistance from non-affected regions of the nation could be scarce or nonexistent. The combination of large area coverage of nuclear EMP and solar GMD effects combined with the high vulnerability and operational criticality of the grid heighten the societal risks of grid failure. Grid failure is an existential threat to the survival of the United States as a nation and to the American population.

The Congressional EMP Commission concluded in its April 2008 Report that grid protection is technically feasible and affordable for both nuclear EMP and solar GMD. EMP effects from nuclear bursts are not new threats to our nation. DoD experience in implementing EMP protection began in the 1960s with the Minuteman system acquisition. Over the last fifty years, the military has hardened a large number of systems and developed protection, testing, and life-cycle maintenance guidelines and standards that provide a sound and proven basis for affordable protection of the electric power grid. Protecting the grid against nuclear EMP also provides protection against solar GMDs. It will be most important that DoD share its experience in hardening and maintaining systems with the electric power industry.<sup>1</sup>

#### **Wide-Area Electromagnetic Environments**

The nuclear electromagnetic pulse (EMP) results from the detonation of a nuclear weapon high above the tropopause. Solar storm geomagnetic disturbances (GMDs) occur naturally when an intense wave of charged particles from the sun perturbs the earth's magnetic field.

In the case of high altitude nuclear bursts, two principal wide-area electromagnetic phenomena affect the electric power system, each with distinct waveform characteristics and system effects:

1. The first, a "prompt" EMP field, also referred to as E1, is created by gamma ray interaction with stratospheric air molecules. It peaks at tens of kilovolts per meter in a few nanoseconds, and lasts a few hundred nanoseconds. E1's broad-band power spectrum (frequency content from DC to 1 GHz) enables it to couple to electrical and electronic systems in general, regardless of the length of their penetrating cables and antenna lines. Induced currents range into the

---

<sup>1</sup> There is a mutual benefit to DoD since 99% of defense installation power is supplied by the commercial electric power grid.

thousands of amperes. Exposed systems may be upset or permanently damaged.

2. The second phenomenon, "late-time" EMP, is also referred to as magnetohydrodynamic (MHD) EMP or E3, and is caused by the distortion of the earth's magnetic field lines due to the expanding nuclear fireball and the rising of heated, ionized layers of the ionosphere. The change of the magnetic field at the earth's surface induces low frequency currents of hundreds to thousands of amperes in long conducting lines (a few kilometers or longer) that damage components of the electric power grid itself as well as connected systems. Long-line communication and data networks, including those using copper as well as fiber-optic signal lines with repeaters, are also vulnerable.

In the case of solar storms, electric power grid effects originate from large excursions in the flux levels of charged particles from the Sun and the interaction of these particles with the Earth's magnetic field. Similar to MHD EMP generation, these particles introduce changes of the magnetic field at the surface of the earth (GMDs) that induce low frequency currents of hundreds to thousands of amperes in long-line systems affecting electric power and communication networks over large regions of the earth's surface.

### **Consequent Wide-Area Electromagnetic System Effects**

EMP and GMD effects are most pronounced for long line networks such as electric power, telecommunications and data networks. While E3 and GMD couple significant energy only to long lines (greater than several kilometers), E1, because of its wide-band nature, couples efficiently to both long lines and local system conductors including antennas, local-area networks, telephone equipment, computer workstations, and SCADA systems.

Empirical evidence of EMP system effects has accrued from both U.S. and Russian atmospheric tests in the 1950s and early 1960s. A U.S. test named "Starfish Prime" in July 1962 involved a 1.4 megaton device detonated at 400 km. The event caused street light failures in Hawaii some 1300 kilometers away. The Russians collected more extensive data than the U.S. since their high altitude nuclear EMP tests occurred over expansive continental land areas. Soviet scientists observed EMP effects due to high altitude nuclear detonation at distances of hundreds of kilometers. Effects on exposed power grid elements included shut-down of power transmission lines, overvoltage-induced punctures of transmission line insulation, lines knocked to the ground due to the failure of mounting insulators on transmission line towers, and transformer fires.

Tests of U.S. equipment in simulated nuclear EMP environments by the EMP Commission indicate that later vintage electronics are more susceptible to EMP transients due to semiconductor device miniaturization and high speed digital processing. An example of effects includes burnout of a GPS system, which exhibited failures at levels as low as 5 KV/m, an effect achievable with low yield, entry-level nuclear weapons. Tests also reveal EMP vulnerabilities in telecommunications switches/routers, cell phone stations, and local multiplexers.

Moderate solar storms have provided empirical evidence that bulk power EHV transformers will fail during solar geomagnetic disturbances. Laboratory tests and analyses of the electric power transmission systems indicate the likelihood of power outages due to transformer and control system debilitation and network reactive power instabilities. Because of the long lead time for manufacturing, difficulty of moving, and expense, replacement of failed large bulk power transformers dominates the grid restoration timeline. Including manufacture time, transformer replacement times range from months to

years. In March 2012 a 345 kV transformer stockpiled by the Department of Homeland Security was replaced in only five days. However, at present, the U.S. electric utility industry lacks large-scale stockpiling of extra high voltage transformers with custom configurations to replace hundreds of concurrently damaged or destroyed transformers.

Research performed for the Congressional EMP Commission indicates that nuclear EMP and large solar storm GMDs can cause debilitating system effects including:

- 1) EMP/E1- caused malfunctions and damage to solid-state relays in electric substations.
- 2) EMP/E1-caused malfunctions and damage to computer controls in power generation facilities, substations, and control centers.
- 3) EMP/E1-caused malfunctions and damage to power system communications.
- 4) EMP/E1-caused flashover and damage to distribution class insulators, sometimes resulting in downed lines.
- 5) EMP/E1-caused flashover and damage to transformers.
- 6) EMP/E3 and GMD-caused voltage collapse of the power grid due to transformer saturation.
- 7) EMP/E3 and GMD-caused damage to extra-high-voltage (EHV) transformers due to internal heating and vibration.

Table 1 provides a summary comparison of nuclear EMP and GMD environment and effects characteristics.

**Table 1. Wide-Area Electromagnetic Electric Power Grid Effects**

Threat	Environment	Characteristics	Maximum Coupling Levels	Susceptible Systems
High Altitude Nuclear Burst	Prompt EMP – E1  Amplitude: 10s of Kilovolts/meter	Broad frequency Bandwidth of 1GHz – couples to short and long conductors	Millions of volts  1000s of amperes	Power Generation and Delivery Networks Including Transformers  Communication/Control Electronics
	MHD EMP – E3  Amplitude: 10s of Volts/kilometer	Low frequency (sub-Hz) Couples efficiently only to long lines	1000s of volts  1000s of amperes	Power Generation and Delivery Networks Including Transformers
Solar Storms	GMD (similar to EMP-E3)  Amplitude: 10s of Volts/kilometer	Low frequency (sub-Hz) Couples efficiently only to long lines	1000s of volts  1000s of amperes	Power Generation and Delivery Networks Including Transformers

**EMP and GMD Protection.**

Importantly, hardening the electric power grid against nuclear EMP also protects the system from solar storm GMD effects. The converse is not true – protecting only against GMD effects does not address EMP/E1 effects.

We know how to protect systems against EMP and GMD. EMP (including E1 and E3 effects) protection has been implemented since the 1960s and standardized since the 1990s by the U.S. Department of Defense. The low risk approach used to protect our nuclear command and control facilities is embodied in MIL-STD-188-125 and MIL-HDBK-423. The approach used in these guides may be applied to grid

communication and control centers and systems. In addition, GMD-specific protection experience accrues from programs in Great Britain, Canada, and Sweden. Because of their northerly latitudes, these countries have experienced severe solar storm effects on their power grids that have led them to develop effective countermeasures.

An initial expedient countermeasure would be to expand the provision of back-up power systems supporting life-line infrastructure systems. This is a lesson learned from past weather disasters, most notably from Hurricanes Katrina and Sandy. Many critical national defense, medical, communication, and financial facilities now have emergency generators. Additional provision of emergency power systems is needed, especially for water supply systems, gas stations, food stores, and pharmacies. Backup power may be provided by generators or new micro-grid technology.

Protection of the grid itself should begin by protecting EHV transformers with ground-induced current (GIC) blocking devices in their neutral to ground connections (see Figure 1). This practice would significantly reduce the probability of grid collapse and transformer damage due to GMD and E3. In addition, E1 overvoltage protection of transformers is achievable by installing common overvoltage protection devices (metal oxide varistors or spark gaps) on transformer terminals. Estimates for protecting the most vulnerable and difficult to replace transformers (extra high-voltage bulk power transformers) in the U.S. range \$1B - \$5B; on an annualized basis, protection of transformers against E3 would cost the equivalent of one postage stamp per person per year.





Figure 1. Transformer Protection Using Neutral Blocking Devices

EMP protection methods (including both E1 and E3) applicable to power grid communication and control systems and facilities have been developed and implemented by DoD and are well-documented. The basic concept is to keep EMP energy away from mission-critical electrical and electronic systems by enclosing them within an electromagnetic barrier. Engineering approaches usually include metal enclosures and protecting each wire penetration with filters and/or voltage limiting devices. Protection also involves assurance of back-up power and provision for hardness surveillance and maintenance.



**Figure 2. Low-Risk EMP Protection Approach for Control and Communication Facility**

Figure 2 illustrates the low-risk protection approach described in MIL-STD-188-125. The standard specifies the following hardening program elements:

- Facility shield. The facility HEMP shield is a continuous conductive enclosure that meets or exceeds specified shielding effectiveness requirements. The shield is normally constructed of a metal, such as steel or copper. Other materials may be used if they can provide the required shielding effectiveness and are fully compatible with the penetration protection and grounding requirements.
- Shield penetrations or points of entry (POEs) including wire penetrations, conduit/pipe penetrations, doors, and apertures. The number of shield POEs is limited to the minimum required for operational, life-safety, and habitability purposes. Each POE is protected with an energy limiting device that satisfies standard performance requirements.
- HEMP testing. The standard requires protection performance certification by test. The protection program includes quality assurance testing during facility construction and equipment installation, acceptance testing for the electromagnetic barriers, and verification testing of the completed and operational facility.
- Hardness Maintenance and Surveillance (HM/HS). HM/HS is included in the facility planning, design, and construction phases to assure that hardness features stay intact over the life cycle of the protected facility and systems.

In summary, the electric power grid is the keystone infrastructure upon which all other critical infrastructures depend—protection of the grid against both nuclear and solar EMP should be a top priority. Engineering practices and technologies to protect against E1 caused by nuclear EMP—as well as E3 caused by both nuclear EMP and solar GMD—are well developed and currently in use by the Department of Defense and/or available from commercial vendors. It will be important for DoD to make its expertise available to DHS, DOE, NRC, FERC and the electric power industry.

## **Letter to President Obama: Appendix 4**

### **Presidential Plan to Protect American Public from Long-Term Electric Grid Outage Due to Geomagnetic Disturbance**

On May 16, 2013 the Federal Energy Regulatory Commission (FERC) issued Order 779 requiring development of reliability standards to protect the Bulk Power System against geomagnetic disturbances (GMD). The vote of the FERC Commissioners was 5-0. This FERC action confirmed that solar storms and resulting GMD are serious threats to the health and safety of the American public. FERC now requires the North American Electric Reliability Corporation (NERC), the FERC-approved Electric Reliability Organization, to develop and submit new GMD standards in a two-stage process.

In the first stage, NERC will have six months to file reliability standards requiring owners and operators of the Bulk-Power System to develop and implement operational procedures to forestall cascading grid collapse during GMD events. This short-term fix, operational procedures, will prop up power reserves during solar storms, but is unlikely to prevent permanent equipment damage and resulting long-term grid outage.

In the second stage, NERC will have 18 months to file standards identifying “benchmark GMD events,” which define the severity of GMD events. Owners and operators will then conduct their own assessments of grid stability during solar storms, and also assess vulnerability of their critical equipment to permanent damage. Only after these assessments will any protective measures for critical equipment—such as extra high voltage transformers—begin to be implemented.

The FERC process and timeline exposes a fundamental shortfall in the protection of the American public; while the solar storm threat has been unambiguously confirmed by a federal body, the public could still be unprotected from long-term grid outage for many years. We propose that existing Presidential authority to de-energize the electric grid fill this shortfall and that a solar storm emergency plan be developed.

A solar storm emergency plan could be legally and operationally supported by a Presidential Executive Order, a DHS National Planning Scenario, a FERC Electric Reliability Order, a NRC Emergency Preparedness Rule, and a DOD Defense Planning Scenario. The President currently has authority to order such an emergency plan; see the attached legal brief, " Legal Authority For The President Of The United States To Order Interruption Of U.S. Electric Generation And Related Electric Grid Protections During A Severe Solar Geomagnetic Storm," authored by William R. Harris.

Advance emergency planning would avoid hasty and potentially ill-considered decisions when a major Coronal Mass Ejection (CME) by the sun has been detected by satellites near the sun, but the impact on the earth has not been confirmed by the Advanced Composition Explorer satellite near the earth. Without an advance plan, the two day transit time for a major CME is likely insufficient to allow for coordination with electric utilities to de-energize the grid.

References:

1. ["Docket No. RM12-22-000; Order No. 779; Reliability Standards for Geomagnetic Disturbances,"](#) FERC, Issued May 16, 2013
2. ["Report of the Commission to Assess the Threat to the United States from Electromagnetic Pulse \(EMP\) Attack; Volume 1: Executive Report,"](#) Commission to Assess the Threat to the United States from Electromagnetic Pulse (EMP) Attack, 2004
3. ["Report of the Commission to Assess the Threat to the United States from Electromagnetic Pulse \(EMP\) Attack; Critical National Infrastructures,"](#) Commission to Assess the Threat to the United States from Electromagnetic Pulse (EMP) Attack, April 2008
4. ["Geomagnetic Storms and Their Impacts on the U.S. Power Grid,"](#) Oak Ridge National Laboratory, January 2010
5. ["Solar Storm Risk to the North American Electric Grid,"](#) Lloyd's and Atmospheric and Environmental Research (AER), Inc., 2013

## Letter to President Obama: Appendix 5

### Legal Authority for the President of the United States to Order Interruption of U.S. Electric Generation and Related Electric Grid Protections during a Severe Solar Geomagnetic Storm

**William R. Harris**

The President of the United States holds powers both enumerated and implied by Article II of the U.S. Constitution, and by the President's role as commander-in-chief. Moreover, the Presidential oath of office to "faithfully execute" the laws provides a duty to fulfill a wide array of presidential functions, including the continuity and functionality of the executive branch, aid to the legislative and judicial branches, fulfillment of treaties and other international agreements, and support to state and local governments. Beyond these powers and responsibilities, the President has duties and powers, many of them delegable to Cabinet secretaries, or others.<sup>1</sup> While the police powers are generally reserved to the states (per the 10<sup>th</sup> Amendment to the federal constitution), the President retains powers granted under the U.S. Constitution and under statutory laws.

Severe solar geomagnetic storms fall under the more general category of high impact, low frequency events that could result in the death of millions of Americans and threaten the existence of the United States as a country. Real-world experience during small solar geomagnetic storms shows that current induced by these storms can overheat and otherwise permanently damage extra high voltage (EHV) transformers used for electric grid transmission. Under normal conditions, the lead time for ordering replacement transformers is months to years; additionally, most EHV transformers are manufactured outside of the United States. As a result, any solar geomagnetic disturbance that results in widespread damage of critical grid infrastructure—including but not limited to EHV transformers—could result in a blackout lasting months or even years. Because the electric grid is the keystone infrastructure upon which all other critical infrastructures depend, long-term grid outage is an existential threat.

Unlike other most other natural disasters that affect only a single state, or several adjoining states, a severe solar geomagnetic storm is more likely to affect a region of the United States, the entire continental U.S., or even multiple countries. During a severe solar storm, it is unlikely that states acting alone will be capable of effectively exercising their police power functions for disaster management, whether through a state public utility commission, or a governor's office of emergency management, or other executive authority. Might instead the federal

---

<sup>1</sup> Title 3, section 301 of the U.S. Code provides a general authorization for presidential delegation of functions, excepting specifically non-delegable functions, so long as these acts of delegation are published in the Federal Register. For example, the duty to maintain a domestic industrial base, including national defense resources preparedness, is a delegation by President Obama in March 2012. See 77 FR 16651 (2012).

government retain the power and duty for emergency preparedness? With warnings of a severe solar geomagnetic storm, might the President have the authority and duty to interrupt electric power generation to protect critical electric infrastructures? Without prompt action supported by the express and implied powers of the President, substantial portions of the North American electric grid might not endure, or might not be expeditiously reconstituted after the emergency has passed. Indeed, the United States as a nation might not endure, absent appropriate exercise of Presidential authority.

What are some of the presidential powers or powers delegated by the President or Congress to subordinate executive officers of the federal government? Title 42 U.S.C. sec. 5195 (P.L. 93-288, Title VI, sec. 601) explains as a purpose the provision of “a system of emergency preparedness for the protection of life and property in the United States.” The Federal Government “*shall* provide necessary direction, coordination, and guidance, and *shall* provide necessary assistance as authorized by the subchapter so that a comprehensive emergency preparedness system exists for all hazards.” (Italics added.) A federal preparedness plan and system to cope with *all hazards* is mandatory, not optional.

The Federal government would likely have multiple sources of confirmation of an impending severe geomagnetic storm, beyond the Advance Composition Explorer (ACE) satellite or its prospective replacement satellite: for example, a variety of National Aeronautical and Space Administration (NASA), or National Reconnaissance Office (NRO) space assets or other Department of Defense space assets might independently confirm an impending solar geomagnetic storm. Notably, these are assets of the federal government, not the several states.

How might the President utilize specified emergency powers that complement Article II presidential powers under the U.S. Constitution? Two statutes are of special interest in anticipating and preparing to protect critical electric grid infrastructure before, during, and after a severe solar geomagnetic disturbance.

The first statute is the Carter era International Emergency Economic Powers Act [P.L. 95-223] and its year 2007 enhancements [P.L. 110-96], the International Emergency Economic Powers Act found at 50 U.S.C. § 1701 et seq. Section 1701, enables a President “to deal with an unusual and extraordinary threat, which has its source in whole or substantial part outside the United States” with impacts upon the national security, foreign policy, or the economy.

A coronal mass ejection from the sun, causing severe geomagnetic disturbance and threat to critical national infrastructure, including the bulk power system, would trigger presidential emergency powers. Importantly, with proper exercise of federal authority, the President and his staff could reasonably anticipate scenarios involving the potential loss of electric grid facilities, and plan for temporary protection of key assets. Many of these assets, such as EHV

transformers, or static (or dynamic) VAR capacitors, might be protected from irreversible damage by a presidential order to de-energize key equipment, while allowing an “operate through” regime for other equipment assessed as having a “withstand” capability or shielded by neutral blocking devices.

Emergency plans and related exercises would require a national inventory of critical assets, including identification of those assets most likely to sustain permanent damage if left unprotected. In contrast, generating facilities without long transmission lines, or operating at lower voltages, or operating where soil conditions might provide some protection against *geomagnetically induced currents* could be candidates to “operate through” all but the most severe solar geomagnetic disturbances. Generation facilities and transmission lines protected by “neutral ground blocking equipment” might also “operate through” solar storms. It would be important that the White House Situation Room, national monitoring facilities, and regional electric balancing authorities keep track of which electric grid assets could be designated as “operate through” assets versus those critical assets that are candidates for prompt *de-energizing*. Mere “de-rating” of equipment, so that generators operate at reduced electric loads, may be insufficient to prevent damage, because an energized transformer at near-zero load can still be vulnerable to both overheating hazards and to vibrational stress.

A second federal statute provides the President specific authority to order the de-energizing of energy facilities that utilize natural gas or petroleum “as a primary energy source” for the duration of “a severe energy supply disruption.” This statute, known as the Powerplant and Industrial Fuel Act of 1978 [P.L. 95-620, found at Title 42 U.S.C. § 8374], anticipated the need for the President to halt uses of natural gas or petroleum products during an international oil embargo or more generally “an energy supply disruption.”

The larger purpose of P.L. 95-620 was to preserve a functional U.S. economy and the public health, safety, and welfare despite a threat to sustainable electricity production and availability of fuel supplies for transportation. The specific scenario linked to this legislation, a disruption of imported oil, may no longer be likely, but the specific, literal authorities of the President remain; and these authorities remain useful to cope with a solar geomagnetic disturbance that requires de-energizing critical electric grid equipment.

Under the Powerplant and Industrial Fuel Use Act, if the President declares a severe energy supply interruption, or anticipates this outcome from future confirmed warnings of severe solar geomagnetic storms, per Title 42 U.S.C. section 8374(a), the President may make findings: that a national or regional fuel shortage exists or may exist; that the effect is likely to be of significant scope and duration, and “of an emergency nature.” Thence, the President may by order –

“prohibit any electric powerplant or major fuel-burning installation from using natural gas or petroleum, or both, as a primary energy source for the duration of such [energy supply] disruption.”

The duration of the emergency Presidential order is limited to the lesser of the “duration” of the emergency or 90 days – which should suffice for the several-day duration of previously observed severe solar geomagnetic storms. Under this statute, the President may not delegate authority to issue relevant orders to other federal officials. [42 U.S.C. § 8374(e).]

What might be the operational use of these two statutes? Assuming development of appropriate equipment databases and communication systems that can operate during severe solar storms, the President might – with prior practice exercises and a validation system to confirm presidential orders – cause the immediate shutdown of all unprotected gas-fired and petroleum-fired electric generation facilities within the bulk power system of the United States.

U.S. Energy Information Administration projections for year 2013 U.S. electric generation, by fuel type, estimate natural-gas electric generation as 27.6% of the annual total, and petroleum at just 0.6% of the annual total, or a combined share of about 28.2% of total electric generation.<sup>2</sup>

Concurrently, the Nuclear Regulatory Commission (NRC) has existing authority to de-energize all 102-licensed nuclear power plants operating under its supervision.<sup>3</sup> Temporary plant shutdown is done routinely during earthquakes and hurricanes under NRC safety authority. At the April 30, 2012 FERC Technical Conference on geomagnetic disturbances and reliability of the bulk power system<sup>4</sup>, an NRC nuclear engineer testified that the prudent course of action before a severe solar geomagnetic storm might be to shut down all NRC licensed power reactors. But since these facilities produce about 18-19% percent of national electric supply, their uncoordinated shutdown would by itself produce a risk of electric grid instability.

With combination of the President’s non-delegable authority to de-energize natural gas and petroleum fired generating facilities, and the NRC’s authority to de-energize 18-19% percent of projected U.S electric generation, generating facilities that will produce about 46-47% of total U.S. electric generation can be protected – either by de-energizing orders or by “operate through” instructions.

In a severe solar storm, might the United States be able to protect a higher share of its critical electric infrastructure than merely 46-47% of annual generating capacity? The largest single

---

<sup>2</sup> See U.S. Energy Information Administration, “Short-Term Energy Outlook,” June 2013.

<sup>3</sup> The two San Onofre (SONGS) power plants in Southern California are now inoperable and scheduled for decommissioning.

<sup>4</sup> See FERC Docket AD12-13-000 (2012).

source of U.S. electric generation, by fuel type, remains coal. The U.S. Energy Information Administration estimates that coal-fired electric generation will remain just above 40% of total U.S. electric generation in years 2013 and 2014.<sup>5</sup>

The President cannot rely upon the Powerplant and Industrial Fuel Use Act of 1978 to de-energize coal-fired power plants because that Act specifically authorizes restrictions on natural gas and petroleum fuels but not coal. It was assumed, in 1978, that coal-fired electric generation would be increased during an energy supply disruption.

Might the President order de-energizing of coal-fired plants before or during an impending solar storm by declaring a national emergency under the International Emergency Economic Powers Act [50 U.S.C. §1701 et seq.], or under the Defense Production Act of 1950 as amended, or under the doctrine of “necessity”?<sup>6</sup> Under our interpretation, the President has these emergency powers, and exercise of these powers in anticipation of a severe solar geomagnetic storm could preserve critical electric grid equipment. Moreover, if actionable intelligence were sufficiently precise, the President could order the de-energizing of all critical but unprotected electric grid equipment in anticipation of a man-made electromagnetic pulse (EMP) attack.

In substance and in law, the President does have emergency powers to order the de-energizing of coal-fired electric generation during a solar geomagnetic storm emergency. However, without express legislative authority—specifically legislation that reverses the implied prohibition of Presidential authorization to de-energize coal-fired electric generation facilities—the federal government might be liable under the U.S. Constitution for the uncompensated “taking” of private property.<sup>7</sup> The Constitutional obligations of the federal government are not waived merely because of the necessity of action.<sup>8</sup> If the President acts to de-energize a regional electric grid or the national electric grid, or if the President declines to act, and the

---

<sup>5</sup> See U.S. Energy Information Administration, “Short-Term Energy Outlook, June 2013.”

<sup>6</sup> Thomas Jefferson wrote of “the unwritten laws of necessity, of self-preservation, and of the public safety, control the written laws....” Letter, Thomas Jefferson to John Colvin, Sept. 20, 1810, in 11 The works of Thomas Jefferson at 146 (Paul Leicester Ford, ed. 1905). Before adoption of the U.S. Constitution, Alexander Hamilton wrote in The Federalist No. 23, “[T]he circumstances which may affect the public safety are [not] reducible within certain determinate limits... there can be no limitation of that authority which is to provide for the defense and protection of the community, in any matter essential to its efficacy....” (December 18, 1787).

<sup>7</sup> “Private property” under the takings clause could include damage to capital equipment, loss of income for electric utilities, and business interruption losses for utility customers. The issuance of a Presidential Order to de-energize generating facilities may have advantages for utility owners compared to their voluntary decision(s) to de-energize their power plants during a severe solar storm. Under many insurance policies the intentional shutdown of a power plant by an insured owner may void insurance coverage against customer claims and for property damage of insureds.

<sup>8</sup> “The American Constitution contains no general provision authorizing suspension of the normal government processes when an emergency is declared by appropriate government authority.” Quoted from Henry P. Monaghan, “The Protective Power of the President,” 93 Colum. L. Rev. 1 at 33 (1993). For a review of presidential emergency powers when supporting legislation does not exist, and when contradictory legislation is in effect see the concurring opinion of Justice Robert Jackson in Youngstown Sheet & Tube Co. v. Sawyer, 343 U.S. 579 (1952).

nation suffers greater losses of human life and harm to the national economy, most likely the President's actions or inactions would be precluded from federal liability under the "discretionary function exception" to the Federal Tort Claims Act.<sup>9</sup>

The primary reason to seek unambiguous legislative authority for the President to order the de-energizing of the U.S. or a regional electric grid is to avert needless pre-decisional delay. Legal authority should be crystal clear, and known to federal and state officials, and by utility operators and regional electric balancing authorities that might be subject to presidential orders, especially if the window of necessary action involves minutes, not hours. Hence, the more prudent course, in anticipation of a severe solar geomagnetic storm or man-made EMP hazard, might be for the President and his legal advisors to seek a clean legislative authorization from the U.S. Congress: to protect critical electric facilities essential to the bulk power system, the national defense, or other critical national infrastructure; and including the authority to order the de-energizing or re-energizing of the bulk power system of the United States or regional entities served by the bulk power system. Anticipating the risk of widespread electric blackouts during a severe geomagnetic storm, any federal legislation to broaden presidential authority to authorize temporary de-energizing of critical electric power generation might also: provide incentives for "grid islanding" to ensure critical electricity supply to hospitals and nursing homes; to provide for continual electricity supply to critical telecommunications systems; and prioritize off-site power to military facilities and nuclear power plants.<sup>10</sup> A temporary but controlled shutdown of the North American electric grid would lead to loss of life and extraordinary economic damage. But the costs of inaction—including the risk of catastrophic grid collapse--appear to be even higher.

Might a Bill introduced in June 2012 in the U.S. House of Representatives, H.R. 2417, be a legislative vehicle to clarify presidential authority to act in anticipation of a severe solar geomagnetic storm?<sup>11</sup> The so-called SHIELD Act, a variant of legislation introduced in prior sessions of the U.S. Congress, would expand the authority of the Federal Energy Regulatory Commission (FERC) to set reliability standards and to provide for cost-recovery for grid-

---

<sup>9</sup> See 28 U.S.C. §2680(a).

<sup>10</sup> Without the design and exercise of reliable emergency communication systems capable of operating through a severe solar geomagnetic storm, the President might be incapable of reliably ordering and authenticating orders to de-energize or re-energize as appropriate electric grid facilities essential to critical national or critical defense infrastructure. President Obama's Executive Order 13618 of July 6, 2012, "Assignment of National Security and Emergency Preparedness Communications Functions," 22 Federal Register 40779, does provide in Sec. 2.2: "The Director of the Office of Science and Technology Policy (OSTP) shall: (a) issue an annual memorandum ... highlighting national priorities for Executive Committee analyses, studies, research and development regarding [National Security and Emergency Preparedness] communications;" and to "advise the President" on radio spectrum prioritization.

<sup>11</sup> On June 18, 2013, twenty Members of Congress filed H.R. 2417, the "Secure High-voltage Infrastructure for Electricity from Lethal Damage (SHIELD) Act." Text is available from the Government Printing Office at <http://www.gpo.gov/fdsys/pkg/BILLS-113hr2417ih/pdf/BILLS-113hr2417ih.pdf>.

protective equipment. This legislation is designed to accelerate protection against both a severe solar geomagnetic storm and man-made electromagnetic pulse (EMP) hazards.<sup>12</sup>

In its as-filed text, H.R. 2417 (113<sup>th</sup> Congress) would create a new Section 215A of the Federal Power Act. Under proposed emergency authorities, if the President issues to the Commission “a written directive or determination identifying an immediate grid security threat,” FERC, a five member commission -

“may, with or without notice, hearing, or report, issue such orders for emergency measures as are necessary in its judgment to protect the reliability of the bulk power system or of defense critical electric infrastructure against such threat.”<sup>13</sup>

The proposed emergency measures would require the assembly of a quorum of FERC Commissioners. Even if the Commissioners acted without notice or public hearing, as would be allowed by the proposed legislation, the FERC Commissioners could not, within the 10 to 20 minute confirmatory warning time of the ACE satellite (or its successor satellite) reliably order the de-energizing of critical electric grid equipment in time to preclude permanent damage. It would appear that authorization by the President, and not a Commission of five presidential appointees, would be necessary.

If the President and his team of legal advisers seek clarifying authority for reliable federal action under inherently short warning time, they might consider either supplementing the proposed authorities in H.R. 2417, or proposing some other legislative vehicle to provide the President the authority to issue emergency orders, including the power to de-energize or re-energize critical electric grid equipment and/or “defense critical electric infrastructure.”

In conclusion: the President, in coordination with the Nuclear Regulatory Commission, has existing authority to de-energize critical U.S. electric grid equipment producing about 46% to 47% of annual U.S. net electric generation. These are the gas-fired, petroleum-fired, and nuclear-fueled electric generating facilities.

The President also has emergency powers to mandate the de-energizing of coal-fired electric generating plants, but with the risk of claims of uncompensated “takings” of property and possible federal liability for tort claims.

---

<sup>12</sup> The Foundation for Resilient Societies is organized in the State of New Hampshire as a non-profit corporation with the mission of conducting research and public education on high-impact, low-frequency risks to societal resilience. The Foundation does not endorse H.R. 2417 or any other specific legislation. In this specific instance, the Foundation contrasts the limits of proposed Presidential authority under H.R. 2417 with the practical necessity of action within a 10-to-20 minute warning time for solar storms, and points out that public safety may require alternative or complementary Presidential authority.

<sup>13</sup> H.R. 2417 (June 18, 2013) at page 8, lines 15-20.

## **Letter to President Obama: Appendix 6**

### Recognizing Electromagnetic Pulse Attack

Electronic upsets and failures occur under normal operating circumstances, even in high-reliability equipment such as that supporting critical infrastructure. EMP-induced upsets and failures, however, are different from those encountered in the normal operation of infrastructure systems, and in fact have unique aspects not encountered under any other circumstances.

EMP produces nearly simultaneous upset and damage of electronic and of other electrical equipment over wide geographic areas, determined by the altitude, character, and explosive yield of the EMP-producing nuclear explosion. Since such upset and damage is not encountered in other circumstances and particularly not remotely to the same scale, the normal experience of otherwise skilled system operators and others in positions of responsibility and authority will not prepare them to identify what has happened to the system, what actions to take to minimize further adverse consequences, and what actions must be carried out to restore the impacted systems as swiftly and effectively as possible.

Special system capabilities and operator awareness, planning, training, and testing will be required to deal with EMP-induced system impacts. The first requirement is for the operators of critical infrastructure systems to be able to determine that a high-altitude nuclear explosion has occurred and has produced a unique set of adverse effects on their systems.

It will be necessary to distinguish high altitude nuclear EMP (HEMP) effects from regional EMP effects that could be generated by a cruise missile or ground based vehicle employing non-nuclear intentional electronic interference devices. These have fast rise times measured in nanoseconds but limited geographic impacts.<sup>1</sup>

That information can be provided by local electromagnetic sensors, by information from Earth satellite systems, or by other means. Whatever the means, the operators and others in positions of authority and responsibility must receive the information immediately. Therefore, the EMP event notification system must itself be highly reliable during and after an EMP attack.

Operators and others in positions of authority and responsibility must be trained to recognize that an EMP attack in fact has taken place, to understand the wide range of effects it can

---

<sup>1</sup> Employment of a high altitude nuclear EMP weapon would violate the U.N. Environmental Modification Convention of 1980 (ENMOD), and the Outer Space Treaty of 1967 (OST). A non-nuclear EMP device might not violate either of these international treaties, and might have only limited impact on electric and electronic devices. For purposes of damage assessment and policy response, it is essential to be able to distinguish these classes of events.

produce, to analyze the status of their infrastructure systems, to avoid further system degradation, to dispatch resources to begin effective system restoration, and to sustain the most critical functions while the system is being repaired and restored. Failures similar to those induced by EMP do not occur in normal system operation, and therefore the training for, and experience developed in the course of, normal system operation will not provide operators with the skills and knowledge-base necessary to perform effectively after EMP-induced system disruption and failure. Training, procedures, simulations, and exercises must be developed and carried out that are specifically designed to contend with EMP-induced effects.

## Letter to President Obama: Appendix 7

### Vulnerability of Nuclear Power Plants to Electromagnetic Pulse

Events at the Fukushima—Daiichi nuclear complex in Japan in March 2011 clearly established that nuclear plants deprived of outside power and without adequate backup systems can pose a catastrophic danger to surrounding populations. While the initiating event for loss of commercial grid power at Fukushima was an earthquake followed by a tsunami, any initiating event causing long-term loss of outside power could result in reactor core damage and boil-off of spent fuel pools, with associated risk of zirconium fuel rod ignition. The resulting fire and spread of dangerous radionuclides could cause the surrounding area to be uninhabitable for centuries. Initiating events could include solar electromagnetic pulse (EMP), nuclear EMP, cyber attack, and coordinated physical attack of critical grid substations.

In October 2010, Oak Ridge National Laboratory released “[Electromagnetic Pulse: Effects on the U.S. Power Grid](#),” a series of comprehensive technical reports for the Federal Energy Regulatory Commission (FERC) in joint sponsorship with the Department of Energy and the Department of Homeland Security. These reports disclose that the commercial power grids in two large areas of the continental United States are vulnerable to solar EMP. The reports conclude that solar activity and resulting large earthbound Coronal Mass Ejection (CME), occurring on average once every one hundred years, would induce a geomagnetic disturbance and cause collapse of the commercial grids in these vulnerable areas. Excess heat from induced currents in transmission lines could permanently damage approximately 350 extra high voltage transformers. The replacement lead time for extra high voltage transformers is approximately 1-2 years. As a result, about two-thirds of nuclear power plants and their associated spent fuel pools would likely be without commercial grid power for a period of 1-2 years.

When extreme value theory is applied to the one-in-one-hundred-year frequency supplied by the Oak Ridge National Laboratory, the resulting probability of long-term loss of outside power is 33% over the standard 40-year licensure term for nuclear power plants and associated spent fuel pools. Loss of outside power with probability of 1% per year and duration of 1-2 years far exceeds the current design basis for nuclear power plants and associated spent fuel pools.

The Foundation for Resilient Societies submitted a proposal to adjust nuclear plant design basis to the NRC as [Petition for Rulemaking PRM-50-96](#) in draft on February 8, 2011 (a full month before the Fukushima disaster) and in final form on March 14, 2011. On December 3, 2012, the NRC determined that “its rulemaking process can appropriately consider a petition on maintaining the safety of used nuclear fuel at U.S. reactors if an extreme solar flare disables the electrical grid.” Moreover, in a [Federal Register Notice](#) on December 18, 2012, the NRC stated that:

“... the NRC has concluded that the expected frequency of such storms is not remote compared to other hazards that the NRC requires NPPs licensees to consider.”

“The NRC believes that it is possible that a geomagnetic storm-induced outage could be long-lasting and could last long enough that the onsite supply of fuel for the emergency generators would be exhausted. “

“It is also possible that a widespread, prolonged grid outage could cause some disruption to society and to the Nation’s infrastructure such that normal commercial deliveries of diesel fuel could be disrupted. In such a situation, it would be prudent for licensees to have procedures in place to address long-term grid collapse scenarios.”

“Solar storms are not specifically identified as natural hazards in GDC 2 [General Design Criteria 2], but the information currently available to the NRC indicates that the frequency of these storms may be consistent with other natural hazards within the intended scope of the GDC.”

“Accordingly, it is appropriate for the NRC to consider regulatory actions that could be needed to ensure adequate protection of public health and safety during and after a severe geomagnetic storm.”

“Thus, the NRC concludes that the petitioner’s scenario is sufficiently credible to require consideration of emergency planning and response capabilities under such circumstances. Accordingly, the NRC intends to further evaluate the petitioner’s concerns in the NRC rulemaking process.”

Petition for Rulemaking PRM-50-96 addressed the consequences of long-term loss of outside power only on spent fuel pools. However, in its ruling on PRM-50-96, the NRC decided on its own initiative to also evaluate the effect of long-term loss of outside power on safe shutdown and core cooling:

“Although outside the scope of this PRM, it should be noted that the NRC, as a part of its core mission to protect public health and safety, is updating its previous evaluation of the effects of geomagnetic storms on systems and components needed to ensure safe shutdown and core cooling at nuclear power reactors.”

In addition to the ongoing evaluation of the NRC, the congressionally-authorized Commission to Assess the Threat to the United States from Electromagnetic Pulse Attack performed a risk assessment of the vulnerability of the U.S. national electric power infrastructure to EMP. This risk assessment is addressed in the Commission's Report on Critical National Infrastructures. Additional Reports are available to authorized persons through the Congress and the Department of Defense.